

THE CORPORATION OF THE TOWNSHIP OF NORTH GLENGARRY
Regular Meeting of Council
Agenda

Monday, May 27, 2024, 6:00 p.m.

Council Chamber

3720 County Road 34

Alexandria, On. K0C 1A0

THE MEETING WILL OPEN WITH THE CANADIAN NATIONAL ANTHEM

- 1. CALL TO ORDER**
- 2. DECLARATIONS OF PECUNIARY INTEREST**
- 3. ACCEPT THE AGENDA (Additions/Deletions)**
- 4. ADOPTION OF PREVIOUS MINUTES**
 - a. Regular Meeting of Council - April 29th 2024
- 5. DELEGATION(S)**
 - a. The Eastern Ontario ATV Club - Butch Thompson, Vice President
- 6. STAFF REPORTS**
 - a. Community Services Department
 1. CIP Application – 6 Main Street South in Maxville
 2. Award Contract for Ice Resurfacer
 - b. Treasury Department
 1. Levying By-Law for Municipal Drain Maintenance
 2. Request for a Minor Improvement on the R.A. McLennan Drain, Real Diotte Branch and Appointment of an Engineer
 - c. Public Works Department
 1. Annual Wastewater Systems Reports for Alexandria and Maxville
 2. Increase to the 2024 CCTV Sewer Budget
- 7. UNFINISHED BUSINESS**
- 8. CONSENT AGENDA**
 - a. RRCA Welcomes New General Manager
 - b. RRCA Board Meeting Highlights - May 16 2024
- 9. NEW BUSINESS**
 - a. AccessAbility Week

10. NOTICE OF MOTION

Next Regular Public Meeting of Council

Monday June 24th at 6:00 p.m. in the Council Chambers, 3720 County Road 34, Alexandria, Ontario.

Note: Meetings are subject to change or cancellation.

11. QUESTION PERIOD

(limit of one question per person and subsequent question will be at the discretion of the Mayor/Chair).

12. CLOSED SESSION BUSINESS

As this matter deals with personal matters about an identifiable individual, including municipal or local board employees they may be discussed in closed session under sections 239 (2)(b) of the *Ontario Municipal Act*

And to adopt the minutes of the Municipal Closed Session of Council meeting on April 8th 2024

13. CONFIRMING BY-LAW

- a. By-law No. 26-2024

14. ADJOURN

THE CORPORATION OF THE TOWNSHIP OF NORTH GLENGARRY

Regular Meeting of Council

Monday, April 29, 2024, 6:00 p.m.

Council Chamber

3720 County Road 34

Alexandria, On. K0C 1A0

PRESENT: Mayor: Jamie MacDonald
Deputy Mayor: Carma Williams
Councillor: Jacques Massie
Councillor: Jeff Manley
Councillor: Michael Madden
Councillor: Brian Caddell
Councillor: Gary Martin

ALSO PRESENT: CAO/Clerk: Sarah Huskinson
Deputy Clerk: Jena Doonan
Director of Community Services: Anne Leduc
Director of the Building/By-law & Planning Services: Jacob Rhéaume
Director of Public Works: Timothy Wright
Treasurer & Director of Finance: Zoe Bougie

1. **CALL TO ORDER**
2. **DECLARATIONS OF PECUNIARY INTEREST**
3. **ACCEPT THE AGENDA (Additions/Deletions)**

Resolution No. 1

Moved by: Brian Caddell

Seconded by: Gary Martin

THAT the Council of the Township of North Glengarry accepts the agenda of the Regular Meeting of Council on Monday April 29 2024.

Carried

4. **ADOPTION OF PREVIOUS MINUTES**

Resolution No. 2

Moved by: Jacques Massie

Seconded by: Brian Caddell

THAT the minutes of the following meeting(s) be adopted as circulated.

Regular Meeting of Council - April 8 2024

Carried

5. DELEGATION(S)

- a. Conservation Authority Act updates and new Regulations- Phil Barnes, Team Lead -Watershed Management

Lead Watershed Management RRCA Team member Phil Barnes updated Council on new regulations, as well as other initiatives and services they offer.

- b. Community Living Glengarry - Danielle Duranceau & Réjean Boulanger

Board members Dan Giroux and Réjean Boulanger along with Danielle Duranceau provided Council with an update regarding their recent strategic planning and its next steps.

6. STAFF REPORTS

- a. Public Works Department

- 1. Sole Sourcing Report – Historic Items

Resolution No. 3

Moved by: Brian Caddell

Seconded by: Gary Martin

THAT the Council of the Township of North Glengarry receives staff report No. PW2024-16, Sole Sourcing Report - Historic Items; and

THAT the Council of the Township of North Glengarry approves the purchasing by negotiation process for the vendors listed in Table 1 for the items listed in Appendix A.

Carried

- 2. Award of Sidewalk Reconstruction Program 2024

Resolution No. 4

Moved by: Jeff Manley

Seconded by: Carma Williams

THAT the Council of the Township of North Glengarry receives Staff Report No. PW2024-17, Award of Sidewalk Reconstruction Program 2024; and

THAT the Council of the Township of North Glengarry authorizes the award of the sidewalk reconstruction program for 2024 to Maylon Excavation for \$96,998.00 plus HST.

Carried

3. Award of Lochiel Garage Roof Replacement

Resolution No. 5

Moved by: Gary Martin

Seconded by: Carma Williams

THAT the Council of the Township of North Glengarry receives Staff Report No. PW 2024-14, Award of Lochiel Garage Roof Replacement; and

THAT the Council of the Township of North Glengarry authorizes the award of the roof replacement to Mille Roches Construction Ltd for \$90,946.00 plus HST.

Carried

4. Award of Dominion Watermain Project 2024

Resolution No. 6

Moved by: Carma Williams

Seconded by: Jeff Manley

THAT the Council of the Township of North Glengarry receives Staff Report No. PW 2024-18, Award of Dominion St Watermain Replacement; and

THAT the Council of the Township of North Glengarry authorizes the award of Dominion St Watermain Replacement to Clarence McDonald Excavation Ltd for \$275,594.00 plus HST; and

THAT the Council of the Township of North Glengarry authorizes the increase of the Dominion St Watermain Budget from \$387,758.00 to \$661,594.00

AND THAT the Council of the Township of North Glengarry authorizes the transfer from the North Glengarry Water Reserve to cover the increase in the Dominion Street Watermain Budget.

Carried

5. Request to the Province to Amend Blue Box Regulation for 'Ineligible' Sources

Resolution No. 7

Moved by: Jeff Manley

Seconded by: Michael Madden

THAT the Council of the Township of North Glengarry receives staff report PW 2024-08, Request to the Province to Amend Blue Box Regulations for 'Ineligible' Sources; and

THAT the Council of the Township of North Glengarry passes the motion to request that the province amends the blue box regulation for ineligible sources as follows:

WHEREAS under Ontario Regulation 391/21: Blue Box producers are fully accountable and financially responsible for their products and packaging once they reach their end of life and are disposed of, for 'eligible' sources only; and

WHEREAS 'ineligible' sources which producers are not responsible for include businesses, places of worship, daycares, campgrounds, public-facing and internal areas of municipal-owned buildings, and not-for-profit organizations, such as shelters and food banks;

AND WHEREAS should a municipality continue to provide services to the 'ineligible' sources, the municipality will be required to oversee the collection, transportation, and processing of the recycling, assuming 100% of the costs;

BE IT RESOLVED that the Council of the Corporation of the Municipality of North Glengarry hereby request that the province amend Ontario Regulation 391/21: Blue Box so that producers are responsible for the end-of-life management of recycling products from all sources;

AND FURTHER that Council hereby request the support of all Ontario Municipalities;

AND FURTHER that this resolution be forwarded to the Honourable Doug Ford, Premier of Ontario, the Honourable Andrea Khanjin, Minister of the Environment, Conservation, and Parks, and the Honourable Graydon Smith, Minister of Natural Resources and Forestry, to MPP of Glengarry, Prescott, Russel, MPP Stéphane Sarrazin, and all Ontario Municipalities.

Carried

6. Award of Storm CCTV

Resolution No. 8

Moved by: Michael Madden

Seconded by: Gary Martin

THAT the Council of the Township of North Glengarry receives Staff Report No. PW 2024-19, Award of Storm CCTV and Cleanout 2024; and

THAT the Council of the Township of North Glengarry authorizes the award of the Storm CCTV and Cleanout to Hydrocam for \$76,619.00 plus HST.

Carried

b. Community Services Department

1. Community Services Capital Projects Update & Community Garden Project

Resolution No. 9

Moved by: Michael Madden

Seconded by: Gary Martin

THAT the Council of the Township of North Glengarry receives Staff Report CS-2024-15 Community Services Capital Projects update and Community Garden Project; and

THAT the Council of the Township of North Glengarry authorizes the reallocation of \$7,500 from the surplus Capital funds remaining from the

Glengarry Sports Palace Capital Budget towards the Community Garden Project at 199 Main Street North in Alexandria.

Carried

2. Economic Development Action Plan Update

Resolution No. 10

Moved by: Brian Caddell

Seconded by: Jeff Manley

THAT the Council of the Township of North Glengarry receives Staff Report CS-2024-16, Economic Development Action Plan Update for information purposes only.

Carried

c. Treasury Department

1. Court of Revision Appointment – Ranger Drain

Resolution No. 11

Moved by: Carma Williams

Seconded by: Michael Madden

THAT the Council of the Township of North Glengarry receives report DR-2024-01 Court of Revision Appointment – Ranger Drain; and

THAT By-Law 23-2024 being a by law to appoint a member of the court revision for the Ranger Municipal Drain be read a first, second and third time and enacted in open Council this 29th day of April 2024.

Carried

d. Planning/Building & By-law Enforcement Department

1. Zoning By-law Amendment No. Z-01-2024

Resolution No. 12

Moved by: Michael Madden

Seconded by: Jeff Manley

THAT the Council of the Township of North Glengarry adopt Zoning By-Law No. Z-01-2024; and

THAT by-law No. Z-01-2024 be read a first, second and third time and adopted in open Council this 29th day of April, 2024.

Carried

2. Zoning By-law Amendment No. Z-02-2024

Resolution No. 13

Moved by: Jeff Manley

Seconded by: Jacques Massie

THAT the Council of the Township of North Glengarry adopt Zoning By-Law No. Z-02-2024.

THAT by-law No. Z-02-2024 be read a first, second and third time and adopted in open Council this 29th day of April, 2024.

Carried

3. Zoning By-law Amendment No. Z-03-2024

Resolution No. 14

Moved by: Gary Martin

Seconded by: Brian Caddell

THAT the Council of the Township of North Glengarry adopt Zoning By-Law No. Z-03-2024.

THAT by-law No. Z-03-2024 be read a first, second and third time and adopted in open Council this 29th day of April, 2024.

Carried

7. **UNFINISHED BUSINESS**

8. **CONSENT AGENDA**

Resolution No. 15

Moved by: Jacques Massie

Seconded by: Michael Madden

THAT the Council of the Township of North Glengarry receives the item(s) from the consent agenda for information purposes only.

Carried

9. **NEW BUSINESS**

10. **NOTICE OF MOTION**

11. **QUESTION PERIOD**

12. **CLOSED SESSION BUSINESS**

13. CONFIRMING BY-LAW

Resolution No. 16

Moved by: Carma Williams

Seconded by: Jeff Manley

THAT the Council of the Township of North Glengarry adopts by-law 25-2024 being a by-law to adopt, confirm and ratify matters dealt with by Resolution; and

THAT By-law 25-2024 be read a first, second, third time and enacted in Open Council this 29th day of April 2024.

Carried

14. ADJOURN

Resolution No. 17

Moved by: Jacques Massie

Seconded by: Brian Caddell

THERE being no further business to discuss, the meeting was adjourned at 7:20 p.m.

Carried

CAO/Clerk/Deputy Clerk

Mayor/Deputy Mayor



ATV Club of Eastern Ontario Inc.

May 13, 2024 – Butch Thompson

ATV Club of Eastern Ontario Inc.

- Not for Profit Corporation (meets monthly)
- 2,000 members
- Run by Volunteers
- Promotes Safe Operation of ATV's
- Approx. 350 km's of ATV Trails
- Member of OFATV (Ontario Federation of ATV Clubs)


ATVCEO Area

- Prescott & Russell
- Stormont, Dundas and / et Glengarry
- Parts of Ex-Ottawa Carleton (east of Hwy 416)
 - Ottawa River to the North
 - Saint-Lawrence River to the South
 - Ontario-Québec Border to the East
 - Hwy 416 to the West


Existing ATV Network in Ontario




Existing ATV Network in Eastern Ontario



Proposed ATV Network Expansion





Existing Trails - North Glengarry (600 series)





Proposed Trails – North Glengarry

Trail #	Trail / Route	From	TO	Distance
613	CR 34 / Main St	McDougal St W	Power Dam Rd	665m
614	Power Dam Rd	CR 34	McCormick Rd	2.7K
615	McCormick Rd	Power Dam Rd	Ouellette Rd	2.0K
616	Ouellette Rd	McCormick Rd	Bush Rd	2.13K
617	McMillian Rd	Ouellette Rd	CR 21	2.2K
618	Old Military Rd	CR 21	Lochinvar Rd	8.73K
619	Lochinvar Rd	Old Military Rd	Aberdeen Rd	4.78K
620	Aberdeen Rd	Lochinvar	Newton Rd (VLKH)	3.45K
621	Tannery Rd	Lochnivar	CR 34	2.0K
622	CR 34	Tannery Rd	Nixon Bdry Rd	753m
			approx.	29.5Kms









Signage



QuadOn App

- Enables access to the approved trail network
- Trail number and status (open/closed),
- Points of Interests (e.g. gas stations, restaurants, motels, scenic spots, parking lots and other services)
- Does not require cell service or WIFI
- Uses the mobile device's built-in GPS

Approvals Required

- United Counties Prescott-Russell
- The Nation Township
- Township of East Hawkesbury
- Township of Champlain
- Township of North Glengarry
- Town of Hawkesbury

Thank You

<https://atv-vtteo.org/>

Questions?



STAFF REPORT TO COUNCIL

Report No: CS-2024-18

May 27, 2024

From: Anne Leduc – Director of Community Services

RE: CIP Application – 6 Main Street South in Maxville

Recommended Motion:

THAT Council receives Staff Report CS-2024-18; and

THAT Council approves the Community Improvement Plan Project for 6 Main Street South, Maxville, Ontario, as submitted by the property owners Cheryl and Ronald Latimer.

- Program B – Building Improvement Grant representing a matching grant of 50% up to a maximum of \$7,500.00 for two façades visible from the street.
- Program C - Commercial Signage, Civic Address Signage and Commercial Awning Grant Program for the Commercial Awning component representing a matching grant of 50% up to a maximum of \$2,500.00.
- Program E – Building Permit Grant representing a grant equal to 100% of the eligible building permit fees to a maximum of \$467.40.
- Program G – Municipal Loan Program of \$10,000.00.

Total Grants: \$10,467.40

Total Loan: \$10,000.00

Background / Analysis:

The property is located at 6 Main Street South in Maxville and is the home to Muir's Bakery on the main floor and one residential apartment on the second floor.

- Supply and install nine (9) white windows on the second floor of the West and South façades.
- Cap wood window frames with white aluminum.
- Replace two (2) front doors. The windows will have white grills and the doors will be painted burgundy.
- Replace "Quarterbell" awning with new steel armature and material. The awning will be burgundy, and the name "Muir's Bakery" will be printed on the material in white.
- Re-install lighting under the awning.
- Re-install original Muir's Bakery signage.
- Building Permit \$467.40

The estimated total cost of the project is \$34,317.40.

Additional work:

- Ground Floor windows, trim and stone sills will be painted white.
- The quote for the awning excludes shipping costs.

Program B – Provides a matching grant of 50% up to \$5,000.00 for one façade and \$7,500.00 for two façades visible from the street

- Applicant was only able to obtain one quote for the proposed work

Contractors	Element	\$ before tax	50%	Eligible
Windows & Doors				
Apple Hill Construction	9 windows, capping of window frames, 2 doors	23,200.00	11,600.00	Yes
				Max. eligible
	TOTAL Eligible Expenses	\$23,200.00	\$11,600.00	\$7,500.00

Program B – total eligible expenses are \$7,500.00

Program C - Provides a matching grant for awnings of 50% up to a maximum of \$2,500.00

- Applicant was only able to obtain one quote for the proposed work

Awning				
Ray Jans Windows & Doors	<ul style="list-style-type: none"> • Design Quarterbell awning – new armature and burgundy material with Muir’s Bakery lettering on the front. 	10,855.00	5,427.50	Yes
				Max. eligible
	TOTAL Eligible Expenses	\$10,855.00	\$5,427.50	\$2,500.00


Program C – total eligible expenses are \$2,500.00

Program E – Provides a matching grant of 100% up to a maximum of \$750.00 for the building permit.

Program E – total eligible amount is \$467.40

Current Photos of the Property

Front View



View driving north on Main Street



Elements for the project

Doors* with white grills inside windows


*Doors identical to picture but are factory painted burgundy



Double-hung windows in white



New Awning model



- Replace “Quarterbell” awning with new steel armature and material. The awning will be burgundy, and the name “Muir’s Bakery” will be printed on the material in white.
- Re-install lighting under the awning.
- **Final art will be sent to Committee prior to approval to go to production.**



Concept Drawing of New Façade *



*Please note that doors will have white grills inside the windows.

Program G – CIP Municipal Loan Program – Provides an interest-free loan to property owners to help finance the restoration, repair, or renovation of the façade of a building that faces a street, park or public gathering space up to a maximum of \$10,000.00 and not to surpass the total cost of the project once other grants are factored in.

Project Costs – Doors, Windows, Awning & Building Permit	
Total Project Estimate	\$34,317.40
• Program B Grants	(\$7,500.00)
• Program C Grants	(\$2,500.00)
• Program E Grant	(\$467.40)
Portion of project estimate remaining	\$23,850.80

Program G – total eligible amount is \$10,000.00

The Arts, Culture and Heritage Committee met on May 21, 2024 to review the CIP for 6 Main Street South in Maxville and recommends that Council approves this project.

Alternatives:

Option 1: Recommended – THAT Council approves the Community Improvement Plan Project for 6 Main Street South, Maxville, Ontario, as submitted by the property owners Cheryl and Ronald Latimer.

- Program B – Building Improvement Grant representing a matching grant of 50% up to a maximum of \$7,500.00 for two façades visible from the street.

- Program C - Commercial Signage, Civic Address Signage and Commercial Awning Grant Program for the Commercial Awning component representing a matching grant of 50% up to a maximum of \$2,500.00.
- Program E – Building Permit Grant representing a grant equal to 100% of the eligible building permit fees to a maximum of 467.40.
- Program G – Municipal Loan Program of \$10,000.00.

Total Grants: \$10,467.40

Total Loan: \$10,000.00

Or

Option 2: Not recommended – THAT Council does not approve this project.

Financial Implications:

Council has approved the 2024 budget which allocates funds for the Community Improvement Plan Program.

A \$10,467.40 grant derived from GL 1-4-1950-3702 would be attributed to the Community Improvement Plan project for the property located at 6 Main Street South, Maxville.

Attachments & Relevant Legislation:

Relevant Legislation: North Glengarry Community Improvement Plan

Others Consulted:

Zoe Bougie – Director of Finance

Ainsley Hunt – Economic Development Officer

Reviewed and Approved by:
Sarah Huskinson, CAO/Clerk



STAFF REPORT TO COUNCIL

Report No: CS-2024-19

May 27, 2024

From: Anne Leduc – Director of Community Services

RE: Award Contract for Ice Resurfacer

Recommended Motion:

THAT Council receives Staff Report CS-2024-19;

THAT Council approves the supply and delivery of one (1) electric Engo Ice Wolf Ice Resurfacer in the amount of \$186,198.00 plus HST;

THAT Council authorizes the Mayor and the CAO to enter into a contract with Engo Equipment Sales Inc. for purchase of this equipment; and

THAT this purchase shall be included and funded through the 2025 Capital Budget.

Background / Analysis:

On March 25, 2024, Council authorized the Capital Expenditure of \$175,000.00 for the purchase of a self-propelled ice resurfacer as part of the Maxville & District Sports Complex' 2025 Capital Budget.

A Request for Tender was issued on March 26, 2024, with a closing date of April 26, 2024. Staff requested bidders to offer pricing on an electric ice resurfacer and on an electric edger. The supply and installation of electric charging units for the ice resurfacer and the electric edger were to be included in the submission prices.

Ice Resurfacer - Three (3) bids were received. The chart below summarizes the qualified bids and the total price listed includes the supply, delivery and freight charges for the units.

ICE RESURFACER	Cost	Leveler Cost	TOTAL
Engo	\$186 198.00	Included in base price	\$ 186 198.00
Zamboni	\$211 988.00	\$ 22 600.00	\$ 234 588.00
Resurface	\$180 568.35	\$ 20 882.40	\$ 201 450.75

Electric edger - Three (3) bids were received. The chart below summarizes the qualified bids and the total price listed includes the supply, delivery and freight charges for the units.

EDGER	Cost	TOTAL
Engo	\$6 102.00	\$6 209.40
Zamboni	\$7 062.50	\$7 186.80
Resurface	\$7 102.05	\$7 227.05

Seeing that the amount for the ice resurfacer surpassed the initial expectation of \$175,000.00, staff propose to postpone the purchase of the electric edger at this time. Only the ice resurfacer will be purchased for a total cost of \$186,198.00.

In its 2023-2027 Corporate Strategy, Council directed staff to promote and encourage environmental stewardship in the Township. The purchase of an electric ice resurfacer would be in line with this Council mandate. As well, as part of its reporting obligations to the Province of Ontario, under the Ontario Regulation 507/18: Broader Public Sector: Energy Reporting and Conservation and Demand Management Plans, the Township of North Glengarry is required to report on the steps it takes to increase energy efficiency and reduce energy costs and greenhouse emissions. The following are the reporting parameters for the Township:

1. A description of current and proposed measures for conserving and otherwise reducing energy consumption and managing its demand for energy.
2. A revised forecast of the expected results of the current and proposed measures.
3. A report of the actual results achieved.
4. A description of any proposed changes to be made to assist the public agency in reaching any targets it has established or forecasts it has made.

Staff expects to have the contract signed and the deposit issued in early June 2024 with a planned delivery for January 2025.

Alternatives:

Option 1 – Recommended - That Council approves the supply and delivery of one (1) electric Engo Ice Wolf Ice Resurfacer for the Maxville & District Sports Complex in the amount of \$186,198.00 plus HST funded through the 2025 Capital Budget.

OR

Option 2 – Not Recommended - That Council declines awarding the contract.

Financial Implications:

At the March 25, 2024, Council authorized the Capital Expenditure of \$175,000.00 for the purchase of a self-propelled ice resurfacer as part of the Maxville & District Sports Complex' 2025 Capital Budget. The 2025 Capital Budget amount will be adjusted to \$186,198.00 plus HST.

Attachments & Relevant Legislation:

- Relevant Legislation – O. Reg. 507/18: Broader Public Sector: Energy Reporting and Conservation and Demand Management Plans
- Reference – Staff Report CS-2024-12 – 2025 Pre-approval of Capital Expenditure – Ice Resurfacer

Others Consulted:

Zoe Bougie – Director of Finance

Nicholas Hansen – Lead Hand – Glengarry Sports Palace

Reviewed and Approved by:
Sarah Huskinson, CAO/Clerk



STAFF REPORT TO COUNCIL

Report No: DR-2024-02

May 27, 2024

From: Zoe Bougie – Director of Finance/Treasurer

RE: Levying By-Law for Municipal Drain Maintenance

Recommended Motion:

THAT the Council of the Township of North Glengarry receives report DR-2024-02 Levying By-Law for Municipal Drain Maintenance;

AND THAT By-Law 24-2024 be read a first, second and third time and enacted in open Council this 27th day of May 2024.

Background / Analysis:

Throughout 2023, eight municipal drains were maintained. In accordance with the Drainage Act, R.S.O. 1990, the maintenance and repair of municipal drains is to be borne by the upstream benefitting property owners, road authority, railways and utilities, less grants received for the work completed. The total cost of drain maintenance to be levied is \$47,186.45 [Table 1]. Of this amount, \$31,603.82 will be charged to landowners and the remaining amount will be charged to the specified authorities as per Table 2.

In North Glengarry, requests for drain maintenance and repair are initiated by a property owner. Property owners pay for the costs of drain maintenance and repair on their property taxes the year following the completion of work. Agricultural property owners that meet the Ontario Ministry of Agriculture and Rural Affairs (OMFRA) qualifications as being an agricultural property will be eligible for a grant up to one third of their costs. The Township of North Glengarry will apply for the grant on behalf of property owners and will bill net of this grant. Any property that was assessed less than \$5.00 will not be billed.

2024 Drain Maintenance Charges			
Ref. Number	Drain Name	Description of Maintenance	Total Amount
LOCD2401	Lacombe Drain	Bottom cleanout and erosion control performed by the Township of East Hawkesbury.	\$3,311.11
LOCD2402	Lower McRae Drain	Bottom cleanout and brushing of the bank slope.	\$13,064.85
LOCD2403	McLeod Creek Drain	Nuisance beaver control and erosion control performed by the Nation Municipality.	\$4,277.63
LOCB2401	R.G. Scott Drain, Branch	Beaver management at outlet.	\$1,054.99
LOCD2404	Ralph McIntosh Drain	Culvert replacement charged to landowner as per engineer's report.	\$3,736.04
LOCD2405	Sabourin Drain	Bottom cleanout and brushing of the bank slope.	\$8,907.77
LOCD2406	Slater-Fraser Drain	Pump house maintenance costs.	\$1,504.55
LOCD2407	Upper McRae Drain	Bottom cleanout and brushing of the bank slope.	\$11,329.51
Total			\$47,186.45

Table 1

2024 Breakdown of Charges	
Organization	Amount
OMFRA Agricultural Grant	\$11,644.88
C.N.R.	\$18.17
Landowner's Share	\$31,603.82
Under \$5.00	\$63.37
Township Beaver Grant	\$361.73
Township of North Glengarry Roads	\$2,608.58
United Counties of SD&G	\$412.41
MTO	\$473.49
Total	\$47,186.45

Table 2

Staff hope to minimize any confusion regarding drainage assessments by sending information prior to the charge being placed on the tax bill. All property owners who will be receiving a charge will receive a letter by mail indicating the name of the drain, the work that was performed, the total cost of maintenance and their share of the total cost. Additionally, staff will include an OMFRA fact sheet explaining what a municipal drain is and how assessments are determined.

Alternatives:

The alternative to not billing out the drain maintenance and repair costs is that costs incurred for drain maintenance and repair will be borne by the general tax levy.

Financial Implications:

The Township of North Glengarry has paid all outstanding invoices for drain maintenance and is now recuperating these costs.

Attachments & Relevant Legislation:

By-Law 24-2024

Others Consulted:

Reviewed and Approved by:
Sarah Huskinson, CAO/Clerk

THE CORPORATION OF THE TOWNSHIP OF NORTH GLENGARRY

BY-LAW NO 24-2024

BEING A BY-LAW TO AUTHORIZE THE LEVYING OF THE COST OF MAINTENANCE COMPLETED ON THE MUNICIPAL DRAINS LISTED HEREIN.

REFERENCE: Section 74 of the Drainage Act, R.S.O. 1990, c. d.17

WHEREAS maintenance was performed on the following drains:

1. Lacombe Drain
2. Lower McRae Drain
3. McLeod Creek Drain
4. R.G. Scott Drain, Branch
5. Ralph McIntosh Drain
6. Sabourin Drain
7. Slater-Fraser Drain
8. Upper McRae Drain

AND WHEREAS the maintenance included the following:

1. Bottom cleanout
2. Bank brushing
3. Erosion control
4. Culvert replacement
5. Pump house maintenance
6. Beaver management

AND WHEREAS the total cost of maintenance was \$47,186.45.

THEREFORE the Council of the Corporation of the Township of North Glengarry enacts as follows:

1. That the Drainage Superintendent proceeded with the maintenance on the following drains according to the existing plan and profile of said drain.
2. That the actual cost of \$47,186.45 for maintaining these municipal drains be assessed to the upstream landowners in proportions determined by the engineer's report as described in the schedule of assessments.
3. That all charges to landowners be placed on the 2024 tax bill for the July and September installment dates. After which time an interest rate of 1.25% per month will be added to the principal which may be outstanding after such time.
4. That all other organizations be sent an invoice for their share of the assessment.
5. That owners with assessments totaling \$5.00 or less will not be charged.

READ a first, second and third time and passed in Open Council this 27th day of May, 2024.

CAO/Clerk/Deputy Clerk

Mayor/Deputy Mayor

I hereby certify this to be a true copy of By-Law No. 24-2024, and that such By-Law is in full force and effect.

Date Certified

CAO/Clerk/Deputy Clerk



STAFF REPORT TO COUNCIL

Report No: DR-2024-03

May 27, 2024

From: Zoe Bougie – Director of Finance/Treasurer

RE: Request for a Minor Improvement on the R.A. McLennan Drain, Real Diotte Branch and Appointment of an Engineer

Recommended Motion:

THAT the Council of the Township of North Glengarry receives report DR-2024-03 Request for a Minor Improvement on the R.A. McLennan Drain, Real Diotte Branch and Appointment of an Engineer;

AND THAT Council accept the request for a minor improvement on the R.A. McLennan Drain, Real Diotte Branch;

AND THAT Shade Group be appointed as the Drainage Engineer for this project.

Background / Analysis:

The Township of North Glengarry received a Section 78(5) request, dated May 2, 2024, through the Drainage Act for a minor improvement to the R.A. McLennan Drain, Real Diotte Branch. The request was received from the owner of the property, Ferme Lavigne Inc.

The improvement involves the installation of a new 30-foot culvert to connect two fields bisected by the municipal drain branch.

As part of the minor improvement process through the Drainage Act, notifications will only be provided to the owner and the regulating authorities. No costs are assessed to any other party other than the requestor/owner.

Staff recommend the appointment of Shade Group as the drainage engineer for this work.

Alternatives:

N/A

Financial Implications:

The requesting landowner is responsible for all costs.

Attachments & Relevant Legislation:

Section 78(5) Minor Improvement Request

Proposed Culvert Location



Minor Improvement Process Flow Chart

Others Consulted:

Monica Shade, P. Eng., Shade Group Inc.

Reviewed and Approved by:
Sarah Huskinson, CAO/Clerk

Minor Improvement Project Procedure under the Drainage Act, 1990.



**Notice of Request for Drain
Minor Improvement
Drainage Act, R.S.O. 1990,
c. D.17, subs. 78 (5)**

To: The Council of the Corporation of the Township of North Glengarry

Re: R.A. McLennan Drain, Real Diotte Branch
(Name of Drain)

In accordance with section 78 (5) of the *Drainage Act*, take notice that I, as owner of land affected, request that the above mentioned drain be improved.

The work being requested is a Minor Improvement Project

I believe that the project being requested meets all the following criteria for a minor improvement project:

- The property owner initiates the improvement on an individual property or two or more adjacent properties that are owned by the same person or the owners are related parties;
- The property owner is paying for costs of the activity, which includes, without limitation engineering construction, contingency costs, incremental future maintenance and eligible municipal administrative costs unless that person and the municipality in which the activity is taking place agree otherwise;
- Carrying out the activity does not require construction access from neighbouring properties or the person initiating the activity has obtained the consent for the construction access from all applicable owners of the neighbouring properties prior to beginning the activity and has provided such proof of consent to the municipality as part of the application to carry out the activity;
- The activity will not result in any changes as to how future repair and maintenance costs are allocated to other property owners in the watershed;
- The activity does not change drainage capacity or erosion potential;
- The activity does not result in the existing drainage works being enclosed; and
- The activity does not take place within any wetlands.

The project can be completed with access from:

- The requestor property
- My neighbour's property and written permission has been granted and attached to this Notice of Request for Minor Drain Improvements form.
- The municipal road right-of-way

a. As owner of land requesting the minor improvement described below, I hereby request pursuant to subsection 78 (5) of the *Drainage Act* that the minor improvement project described immediately below be approved. I acknowledge responsibility for all costs of the minor improvement project, even if the minor improvement project does not proceed.

Provide a more specific description of the proposed drain improvement you are requesting

We would like to add a wide cross over between our two fields which will ensure that we no longer have to use the neighbours alley nor go through her field to get to ours.

Property Owners

- Requestors of minor improvement projects become financially responsible as soon as they sign a request and it is accepted by council as a minor improvement project.
- Your municipal property tax bill will provide the property description and parcel roll number.
- In rural areas, the property description should be in the form of (part) lot and concession and civic address.
- In urban areas, the property description should be in the form of street address and lot and plan number, if available.

Property Description

Ste-Anne Rd (adjacent of #22080)
CON 3 PT LOT 5

Ward or Geographic Township
Lochiel

Parcel Roll Number
0111 016 00713002.0000

If the property is owned in partnership, all partners must be listed. If the property is owned by a corporation, list the corporation's name and the name and corporate position of the authorized officer. Only the owner of the property may request a drain improvement.

I hereby request approval for the minor improvement project for the land described above and acknowledge my/our financial obligations.

Ownership

Corporation If you need to provide additional information, please attach along with this form.

Corporation (The individual with authority to bind the corporation must sign the form)


Name of Signing Officer (Last, First Name) (Type/Print)
Lavigne, Jean-Pierre

Position Title
treasurer

Name of Corporation
Ferme Lavigne Inc

I have the authority to bind the Corporation.

Signature



Date (yyyy/mm/dd)
2024/05/02

Enter the mailing address and primary contact information of property owner below:

Last Name
Lavigne

First Name
Jean-Pierre

Middle Initial

Mailing Address

Unit Number

Street Number
270

Street Name
Concession 9

PO Box

City/Town
Ste-Anne-de-Prescott

Province
Ontario

Postal Code
K0B 1M0

Telephone Number
438-874-1592

Cell Phone Number (Optional)
438-874-1593

Email Address (Optional)
jpshana@gmail.com


To be completed by recipient municipality:

Notice filed this 2 day of May 20 24


Name of Clerk (Last, First Name)

Huskinson, Sarah

Signature of Clerk



**R.A. MacLennan Drain, Real Diotte Branch
Section 78(5) Request**





STAFF REPORT TO COUNCIL

Report No: PW 2024-15

May 13, 2024

From: Timothy Wright, Director of Public Works

RE: Annual Wastewater Systems Reports for Alexandria and Maxville

Recommended Motion:

THAT Council receives Staff Report No. PW 2024-15, Annual Wastewater Systems Reports for Alexandria and Maxville for information purposes only.

Background / Analysis:

Staff have prepared the annual reports for the Alexandria Wastewater System and the Maxville Wastewater System, as per the requirements within the Environmental Compliance Approvals (ECA) for each system.

The attached annual reports were sent to the Ministry of the Environment and posted to the North Glengarry Township’s website for public access, as part of the Township’s obligation.

Financial Implications:

N/A

Attachments & Relevant Legislation:

- Alexandria Wastewater System 2022 Annual Report
- Maxville Wastewater System 2022 Annual Report
- Annual Drinking Water Systems Annual Report to Council

Others Consulted:

Angela Cullen, Compliance Coordinator
Dean McDonald, Environmental Services Manager

Reviewed and approved by:

Alexandria Wastewater System

2023 Annual Report

Contents

- A. System Overview**
- B. Performance Assessment**
- C. Groundwater Monitoring**
- D. Operational Problems Summary**
- E. Maintenance Summary**
- F. Effluent Quality Control and Assurances**
- G. Flow Measurements and Equipment Calibration**
- H. Effluent Objectives**
- I. Lagoon Cell Sludge Accumulation**
- J. Complaints**
- K. By-Pass, Overflow, Spill or Abnormal Discharge Event**
- L. Other**
 - ESO 2000 Summary**
 - i. Equipment Summary**
 - Authorized System Alterations**
 - i. Alterations Summary**
 - Efforts to Reduce System Overflows**
 - i. Collection System Inspection, Repair and Remediation Summary**
 - Proposed Construction of Works Update**
 - i. Status Update**

Appendix A: Wastewater Treatment Works Performance Results

Appendix B: Sludge Monitoring

Appendix C: Annual By-Pass Report

Appendix D: Groundwater Well Monitoring

A. System Overview

Summary of all system components and designations.

The Alexandria wastewater system is owned and operated by the Corporation of the Township of North Glengarry. The sewage system is comprised of a class 2 wastewater collection system and a class 2 continuous discharge treatment facility. The system was originally constructed in the late 1960's with various upgrades throughout the years to improve capacity and treatment.

The wastewater systems operate under 2 Environmental Compliance Approvals (ECA). ECA # 181-W601, issued in October 2023 for all municipal sewage collection systems located within the North Glengarry Township boundaries and ECA # 9873-BQ6LTR, issued in 2021 for the Alexandria Sewage Works, which outlined the proposed upgrades, current conditions and transitional monitoring requirements over a 5-year period. To date no work has been started or completed at the Lagoon system to increase design capacity.

The collection system is comprised of approximately 25.0kms of sanitary sewage collection piping and force mains of various sizes, with approximately 1585 service connections, 3 sanitary lift stations and 1 main pumping station.

The treatment system is a conventional facultative lagoon system comprised of an aeration cell, followed by coagulant addition for phosphorous removal, 3 facultative cells that run-in series towards a disinfection and dechlorination chamber, which finally discharges to an unnamed drain prior to entering the Delisle river. Sodium Hypochlorite is used to disinfect the treated wastewater, while sodium bisulfate is used to dechlorinate the effluent wastewater prior to discharge into the receiver.


B. Performance Assessment

Summary and interpretation of all influent and imported sewage, monitoring data, and a comparison to the effluent limits outlined in condition 7, including an overview of success and adequacy of works.

During the 2023 calendar year 1,480,848 m³ of raw untreated sewage was directed towards the Alexandria Lagoon Treatment Facility, based on the metered effluent flows from the main pumping station. This sewage is mainly comprised of residential and commercial waste, as well as a seasonal RV dumping station, which is only in service between May 15-October 15 annually. Flow trending throughout 2023 was observed to be higher than the previous year total flows, but historical trending indicated that the flows were similar to the 2019 values, see Figure 1 below.

There were no noted incidents of surface water from the Garry River system entering the wet well and no leachate was introduced into the system upstream of the main station during this reporting period. Historically the system has observed significant inflow and infiltration but has made efforts over the last few years to reduce or eliminate the infiltration through spot repairs and system CCTV inspections.

Figure 1: 5-yr Main Station Flow Comparison



Overall, the system operated well throughout 2023 and produced final effluent that met the Provincial ECA Design Objectives, Effluent Compliance Limits and Federal Wastewater Systems Effluent Limits. As an effort to review the characteristic and historical trending of the sewage concentration and treatment efficiency, 5-year sampling comparisons were tabulated below.

The imported landfill leachate monitoring only started in 2021 and sampling is completed on a monthly and quarterly frequency during hauling. As previously mentioned, no leachate was imported into the system during 2023, so no sampling was done. Results from 2021 and 2022 indicated little change to the leachate strength during the spring program.

Table 1: 5-year Imported Leachate Result Comparison (Schedule D):

Parameter	Imported Sewage Annual Average Concentration				
	2019	2020	2021	2022	2023
BOD ₅	n/r	n/r	3 mg/L	3 mg/L	n/r
TSS	n/r	n/r	3 mg/L	5 mg/L	n/r
TP	n/r	n/r	0.08 mg/L	0.02 mg/L	n/r
TKN	n/r	n/r	11.6 mg/L	16.6 mg/L	n/r
Boron	n/r	n/r	0.825 mg/L	0.837 mg/L	n/r
Cobalt	n/r	n/r	0.005 mg/L	0.0006 mg/L	n/r
Magnesium	n/r	n/r	16.8 mg/L	17.2 mg/L	n/r
Manganese	n/r	n/r	0.058 mg/L	0.069 mg/L	n/r
Potassium	n/r	n/r	20.7 mg/L	18.7 mg/L	n/r
Strontium	n/r	n/r	0.740 mg/L	0.773 mg/L	n/r
Bis (2-ethylhexyl) Phthalate	n/r	n/r	< 5 µg/L	5 µg/L	n/r

The influent sewage was sampled monthly and when compared the results to previous years, the influent sewage strength is comparable, which indicates no significant changes or abnormal discharges into the collection system.

Table 2: 5-year Influent Sewage Sampling Result Comparison (Schedule D):

Parameters	Influent Sewage Annual Average Concentration				
	2019	2020	2021	2022	2023
BOD ₅	222 mg/L	160 mg/L	116 mg/L	108 mg/L	90 mg/L
TSS	174 mg/L	300 mg/L	269 mg/L	306 mg/L	209 mg/L
TP	2.53 mg/L	3.33 mg/L	3.25 mg/L	3.11 mg/L	2.70 mg/L
TKN	20.65 mg/L	20.80 mg/L	20.65 mg/L	20.76 mg/L	16.94 mg/L

The aeration outfall was sampled weekly and monthly, as per the minimum requirements per parameter. When the results were compared to previous years, a significant drop in CBOD₅ can be noted indicating good BOD reductions and some treatment shortfalls may be noted in the nitrification treatment cycle.

Table 3: 5-year Aerated Cell Effluent Sampling Result Comparison (Schedule D):

Effluent Parameter	Aerated Cell Annual Average Concentration				
	2019	2020	2021	2022	2023
CBOD ₅	86 mg/L	21 mg/L	16 mg/L	15 mg/L	15 mg/L
TSS	196 mg/L	70 mg/L	83 mg/L	117 mg/L	92 mg/L
TP	2.73 mg/L	1.36 mg/L	1.64 mg/L	2.41 mg/L	2.13 mg/L
Total Ammonia (N)	4.96 mg/L	9.73 mg/L	8.53 mg/L	8.62 mg/L	4.91 mg/L
Nitrite	0.09 mg/L	0.26 mg/L	0.65 mg/L	0.98 mg/L	1.11 mg/L
Nitrate	0.25 mg/L	1.97 mg/L	4.02 mg/L	2.49 mg/L	4.19 mg/L
pH	7.53	7.59	7.56	7.66	7.57
Temperature	11.4°C	11.6°C	12.7°C	11.5°C	12.5°C

The final effluent discharge was sampled and tested on a weekly frequency, as per the ECA minimum requirements. All calculated annual averages for 2023 were found to be well below the design objectives, please refer to section H and Appendix A for further discussion on 2023 results. When compared to previous results, treatment efficiencies have improved over time.

Table 4: 5-year Final Effluent Sampling Sewage Comparison (Schedule D):

Effluent Parameter	Lagoon Effluent Annual Average Concentration				
	2019	2020	2021	2022	2023
CBOD ₅	18.9 mg/L	7.2 mg/L	3.3 mg/L	3.7 mg/L	3.8 mg/L
TSS	24.3 mg/L	9.9 mg/L	4.7 mg/L	6.5 mg/L	6.0 mg/L
TP	0.44 mg/L	0.22 mg/L	0.15 mg/L	0.19 mg/L	0.14 mg/L
Total Ammonia (N)	5.15 mg/L	6.39 mg/L	4.83 mg/L	4.79 mg/L	2.91 mg/L
TKN	9.74 mg/L	8.84 mg/L	7.15 mg/L	7.34 mg/L	4.73 mg/L
Nitrite	0.09 mg/L	0.13 mg/L	0.12 mg/L	0.15 mg/L	0.06 mg/L
Nitrate	0.94 mg/L	0.67 mg/L	0.45 mg/L	0.29 mg/L	0.43 mg/L
E. Coli (geometric mean density)	4.1 cfu/100mL	0 cfu/100mL	1.3 cfu/100mL	2.0 cfu/100mL	2.0 cfu/100mL
Total Chlorine Residual	0.01 mg/L	0.01 mg/L	0.00 mg/L	0.00 mg/L	0.00 mg/L
Dissolved Oxygen	7.07 mg/L	7.95 mg/L	9.16 mg/L	8.15 mg/L	8.58 mg/L
pH	7.53	7.49	7.80	7.64	7.62
Temperature	9.5°C	11.4°C	12.6°C	11.3°C	12.0°C
Un-ionized Ammonia	0.25 mg/L	0.07 mg/L	0.05 mg/L	0.06 mg/L	0.03 mg/L

C. Groundwater Monitoring

Summary and interpretation of all ground water monitoring data

A groundwater monitoring plan was prepared in 2012 by McIntosh Perry and submitted to the MOE, and as part of monitoring requirements, the Township had the 2 monitoring wells installed and developed on March 5, 2013. Background results taken on March 6, 2013 are used to compare the more recent results in order to indicate the potential impact on the surrounding environment.

Operational staff sample annually in March and the 2023 results were similar to previous findings, in that no major impacts were observed in the downstream results. There was a noted increase in upstream nitrate, but no other parameters were elevated. It should be noted the total ammonia was inadvertently left off sampling request, but historically the downstream samples have been gradually increasing since 2017. Please refer to Table 5 below for summary and Appendix D for full summary of results.

Table 5: Groundwater Monitoring Well Sampling Program:

Parameter	Monitoring Well #1		Monitoring Well #2	
	Background results (March 6, 2013)	2023 Sampling Results (March 07, 2023)	Background results (March 6, 2013)	2023 Sampling Results (March 07, 2023)
TOC	8 mg/L	6.2 mg/L	15.2 mg/L	3.3 mg/L
TP	3.8 mg/L	0.73 mg/L	0.47 mg/L	0.40 mg/L
TKN	0.83 mg/L	0.70 mg/L	1.12 mg/L	0.40 mg/L
Total Ammonia (N)	< 0.01 mg/L	n/a	0.22 mg/L	n/a
Nitrite	< 0.1 mg/L	< 0.05 mg/L	0.5 mg/L	< 0.05 mg/L
Nitrate	< 0.1 mg/L	0.05 mg/L	<0.1 mg/L	0.57 mg/L
E. coli	<2 cfu/100 mL	0 /100 mL	<2 cfu/100 mL	0/100 mL

D. Operational Problems

Description of any operating problems encountered, and corrective actions taken.

Collection System:

- Well level monitoring equipment failure due to internal relay board.
 - A secondary float system was used to maintain operations until defective parts were replaced.
- Float issues causing pump to not run as per design.
 - Cleaned and/or adjusted floats to return to normal operations.
- Pump operation issues or failures.
 - Backwash pumps due to air lock caused by performed maintenance.
 - Reset, reverse, or pull pump to remove debris from impeller and restore operations.
 - Unplanned utility power failure.
 - Hydro One repaired external issues, generator or pump installed to maintain operations until repairs completed.
 - Pump position misalignment due to defective guiderails.
 - Replace defective units and proactively replace other pump guiderails to prevent reoccurrence.

- Generator issues
 - Radiator replaced due to slow leak.
 - Breaker trip causing pump failure during power outage, reset to restore operations.
 - External contractor inspected generator to determine cause of underperformance.
 - Installed auxiliary fuel pump which was causing performance issues.
- Alarm panel failure to communicate.
 - External contractor replaced defective equipment to restore communications.

Treatment System:

- Aerator Failure
 - Replaced defective coupler and restore operations.
- Chemical dosage pump issue or loss of dosing.
 - Electrical failure due to power surge from utility power failure
 - Remove defective pump and replace it with spare unit until original pump was repaired and reinstalled.
 - Chemical leak from dosing pump.
 - switch over to back-up pump to maintain operations.
 - pump removed and repaired before reinstallation and placed back into service.
 - Pump air lock.
 - switch over chemical tank and prime all lines in order to remove air.
 - Fitting damage due to corrosion
 - change all defective equipment and material after the chemical dosing pump.
- Chemical dosage line blockage.
 - Transfer injection to spare lines and thaw affected lines to restore chemical dosing.
 - Install a new heat tracer to prevent reoccurrence.
- Unplanned utility power failure
 - Hydro One repaired external issues, generator installed to maintain chemical dosing operations until repairs completed.

E. Maintenance

Summary of all maintenance carried out on any structure, equipment, apparatus, mechanism, or thing forming part of the works.

Collection System:

- Preventative Maintenance Program.
 - schedule and forms at all stations, as required.
 - tasks completed as scheduled.
- Monthly pest control at various sites.
- Bi-annual calibration of all gas monitoring equipment.
- Annual level monitoring and flow measurement calibrations.
- Annual generator maintenance and load testing.
- Annual wet well cleaning at all stations.

Treatment System:

- Preventative Maintenance program
 - schedule and forms at all stations, as required.
 - tasks completed as scheduled.
- Replace chemical dosing lines.
 - change line diameter to prevent crystallization.

- Monthly pest control.
- Annual analyzers, level monitoring and flow measurement calibrations.

F. Effluent Quality Control and Assurance

Summary of any effluent quality assurance or control measures undertaken in the reporting period.

All parameter sampling was performed within provincial and federal guidelines by licensed operational staff, as per internal SOP. Staff are internally trained to ensure techniques and procedures are followed and testing is performed.

An internal weekly sampling schedule with sign off, is used to communicate to all operational staff sampling requirements and timelines. All sampling requirements are reviewed annually to ensure scheduling is up to date and in-line with provincial and federal requirements. As per the ECA requirement, the sampling date was rotated from Wednesdays to Tuesdays during the 2023 reporting period.

Effluent quality control and assurance measures were undertaken by the accredited certified laboratories, Caduceon Environmental and AGAT, who are contracted to complete all sample analysis for the Township of North Glengarry.

G. Flow Measurement and Equipment Calibration

Summary of the calibration and maintenance carried out on all effluent monitoring equipment.

Annual calibrations on the detection units (pumping station level indicators and chemical tank level indicators), and flow sensing devices (magmeter, miltronics, etc.) were completed by St-Laurent Instrumentation between November and December 2023. All handheld and benchtop analyzers were calibrated by ClearTech in July 2023. No issues were noted in regard to the operation of the equipment.

H. Effluent Objectives

Description of effort made, and results achieved in meeting the effluent objectives of condition 6.

The wastewater sewage works ECA is conditional on proposed system upgrades and contains descriptions and provisions for existing and post-construction works. At this time, no construction has been started or completed, so the effluent design objectives and limits have not transitioned from the “prior to completion of construction” values found in schedule B and Schedule C.

Monthly discharge effluent monitoring showed that the effluent design objectives and limits were met and greatly exceeded during this reporting period. Table 6 shows a monthly summary of these parameters. Please refer to Appendix A for a full summary of flows, sampling quality analysis for the Alexandria Sewage Treatment Works. All municipal utility monitoring program reports were sent into the environmental monitoring and reporting branch of the Ministry of the Environment electronically for each month.

Table 6: Monthly Average Final Effluent Sampling Summary

	CBOD ₅	TSS	TP	Total Chlorine Residual	pH		E. Coli (geometric mean density)
	(mg/L)	(mg/L)	(mg/L)	(mg/L)	Min	Max	(organisms/100 mL)
<i>Concentration Limits</i>	30	40	0.5 mg/L	0.2 mg/L	6.0	9.5	< 200
<i>Concentration Objective</i>	25	25	0.4 mg/L	non-detect	6.5	8.5	< 150
January	3.2	4.6	0.15	0.00	7.00	8.07	5.8
February	3.8	6.3	0.20	0.00	7.05	7.89	1.9
March	3.8	7.5	0.26	0.00	6.95	8.67	5.6
April	4.8	12.0	0.17	0.00	7.68	8.32	8.9
May	3.0	3.6	0.10	0.00	7.45	8.27	1.3
June	6.5	7.0	0.10	0.00	7.30	8.31	1.0
July	3.0	3.5	0.11	0.00	7.30	8.64	1.2
August	3.0	4.2	0.06	0.00	7.01	8.20	1.0
September	4.0	5.0	0.05	0.00	7.00	7.61	1.0
October	3.0	3.8	0.10	0.00	7.18	7.92	1.8
November	3.8	4.0	0.16	0.00	7.53	7.91	1.2
December	3.8	11.0	0.20	0.00	7.00	8.63	1.7

Quarterly monitoring included acute lethality for rainbow trout and daphnia, as per Federal WSER and Provincial ECA requirements. All samples were found to not be acutely lethal, and no additional sampling was required during this reporting period.

Table 7: Acute Lethality Testing Summary

Date	Rainbow Trout Lethality Result (%)	Comment	Daphnia Lethality Result (%)	Comment
17-Jan-2023	10	Pass	0	Pass
25-Apr-2023	0	Pass	0	Pass
18-Jul-2023	0	Pass	0	Pass
17-Oct-2023	10	Pass	0	Pass

Additional quarterly monitoring has been undertaken by the Water Works Department since 2019, due to previous adverse results consistently noted under ice cover. In response to this event, a technical memo was prepared by McIntosh Perry in consultations with Wood Environment & Infrastructure Solutions and sent to Environment Canada in June. The recommended actions included continued testing for lethality, metals, inorganic and VOC sampling quarterly until upgrades are completed and commissioned.

The summary in Table 8 below lists all results that exceeded the Provincial Water Quality Objectives. As per the technical memo, the parameters listed do not appear to cause lethality, as most results were lower than 2019 values and lethality was not observed during the testing periods. It is believed that treatment short-circuiting occurred through the aeration chamber

and intermittent aerator failures attributed to the previous exceedances. Measures have been put into place to prevent the short-circuiting until repairs can be completed.

Table 8: Additional Metal, Inorganic and VOC Elevated Results


Parameter	Last Adverse		2023 Result (mg/L)				
	Date	Result	PWQO Standard	Q1	Q2	Q3	Q4
Toluene (µg/L)	28-Oct-2022	2.01	0.8	0.48	0.66	< 0.20	< 0.20
Un-Ionized Ammonia (mg/L)	25-Apr-2023	0.047	0.02	0.101	0.047	0.007	0.009
Total Phosphorus (mg/L)	04-Mar-2020	0.31	*	0.11	0.02	< 0.02	< 0.02
Dissolved Aluminum (mg/L)	22-Mar-2020	0.078	0.075 mg/L	0.031	0.042	0.018	0.015
Total Cobalt (mg/L)	17-Mar-2021	0.0014	0.0009 mg/L	< 0.0005	< 0.0005	< 0.0005	< 0.0005
Total Copper (mg/L)	2-Apr-2020	0.028	0.005 mg/L	0.003	0.002	0.001	0.002
Total Silver (mg/L)	19-Jan-2022	0.0002	0.0001 mg/L	< 0.0001	< 0.0001	< 0.0001	< 0.0001
Total Zinc (mg/L)	19-Jan-2022	0.050	0.03 mg/L	0.029	0.028	< 0.020	< 0.020

*Interim standard at this time, evidence is insufficient to develop a firm objective general guideline established

There were no reports made in regard to floating or settleable solids or that the wastewater contained oil or any other substance that created a visible film, sheen, foam, or discoloration to the receiving waters.

Annual flow summaries indicate a calculated average daily flow of 4,057m³/day, which represents 125% of the total rated capacity for this facility, which is out of compliance. The flows have increased 27% from the previous year and have been gradually increasing over the last 3 years, despite continued efforts to reduce infiltration and inflow. The observed maximum daily flow for the year was reported to be 19,897m³/day, which was reported at the beginning of May, coinciding with a major rain event and the tail end of spring melt conditions. Other significant impacting factors on flows were after 4 separate large rain events outside of the spring melt. Please refer to figure 2 below and to Appendix A for a full summary of flows for the Alexandria Sewage Treatment Works.

Figure 2: Main Station Monthly Flow Comparison



I. Lagoon Cell Sludge Accumulation

Tabulation of the volume of sludge generated in the reporting period, an outline of anticipated volumes to be generated in the next reporting period and summary of the locations to where the sludge was disposed.

A Sludge Management Plan was created by McIntosh Perry and put into place in 2008. As part of monitoring methods, it is recommended sludge levels are to be collected annually by staff. The levels in all 3 cells were measured on October 13, 2023. Based on recorded values, the sludge levels have increased 2.7% in cells A and 9.5% in cell B, but decreased 2% in Cell C. The warning triggers for total sludge volume have been exceeded in Cell B and C, which is consistent with previous years observations.

Efforts to reduce sludge levels in Cell B were restarted in 2021 by contracting Bishop Water for a multi-year Geotube project. During this reporting period no sludge removal was completed due to an excessive amount of vegetation growth within the cell berms during the planned work period, where removal would have created greater time delays and additional inhibitive cost restraints. The work plan going forward will be targeted to starting work in the spring to ensure this issue does not reoccur. Minimal amounts of dewatering were observed from the Geotubes between May and October, nonetheless the water collected from the trench was recycled back into lagoon at Cell B via small sump pump. The dewatering effluent quality was not analyzed nor was the pumped volume tracked.

Table 9: Desludging Operation Summary

Week	BDT	Volume Pumped	Total Polymer Usage	Average Polymer Dosage
		m ³	L	kg/BDT
N/A				
Total				

J. Complaints

Summary of any complaints received during the reporting period and any steps taken to address the complaints.

There were only about a dozen received complaints from homeowners, the majority of these complaints were in regard to sewer lateral back-up. In most cases, the issues were on the homeowner’s side resulting in private contracted services. In a few cases the laterals were inspected through CCTV, and services were repaired, or arrangements were made to repair by township if the problem was found to be on township side.

K. Bypass, Overflow, Spill, Abnormal Discharge Events

Summary of all bypasses, spills, or abnormal discharge event.

There were four primary overflow events reported during 2023. All events were observed in the wastewater collection system at the identified overflow point and coincided with significant rain events and equipment failures. The overflows were reported to the EOHU and SAC, and samples were collected as per requirements and reports were submitted as required. The total annual volume for overflows was estimated to be 10,353m³, with 7,909m³ being metered and 2,444m³ estimated. A summary of the report submission can be found in table below, please refer to Appendix C for an overflow breakdown and report.

Table 10: Overflow Report Submission Summary

# Event	Date	Reported to	Reference Number	Location
1	05-April-2023	<input checked="" type="checkbox"/> Ministry of Health <input checked="" type="checkbox"/> Spills Action Center	1-34P251	Alexandria Main Pumping Station
2	05-April-2023	<input checked="" type="checkbox"/> Ministry of Health <input checked="" type="checkbox"/> Spills Action Center	1-34JV14	Bishop Pumping Station
3	01-May-2023	<input checked="" type="checkbox"/> Ministry of Health <input checked="" type="checkbox"/> Spills Action Center	1-3FQZFB	Alexandria Main Pumping Station
4	01-May-2023	<input checked="" type="checkbox"/> Ministry of Health <input checked="" type="checkbox"/> Spills Action Center	1-3FPH7L	Alexandria Manhole 160 (Centre St Overflow 2)

Quarterly reports for bypasses and overflows are now required to be submitted to Ministry of the Environment inspector as per the ECA.

Table 11: Quarterly Bypass and Overflow Report Submission Summary

Quarter	Month	Year	By-Pass Occur	Overflow Occur	Submitted to MECP	Report Name
1	January-March	2023	N	N	13-Apr-2023	2023-ALX WWS-Bypass and Overflow_ Q1
2	April-June	2023	N	Y	11-Jul-2023	2023-ALX WWS-Bypass and Overflow_ Q2
3	July- September	2023	N	N	12-Aug-2023	2023-ALX WWS-Bypass and Overflow_ Q3
4	October- December	2023	N	N	07-Feb-2024	2023-ALX WWS-Bypass and Overflow_ Q4

L. Other

Any other information the District Manager requires from time to time.

EOS 2000

i. Equipment Summary

The date of installation and removal of the EOS-2000 unit within each unit

The EOS unit was not installed or operated during this reporting period, so as such there was no additional monitoring completed.

Authorized System Alterations

i. Alterations Summary

A summary of all alterations within the reporting period as authorized by the ECA, including all alterations that pose a significant drinking water threat.

There were no alterations or additions to the collection or treatment systems during this reporting period.

Efforts to Reduce System Overflows

i. Collection System Inspection, Repair and Remediation Summary

A summary of all works completed within the reporting period as authorized by the ECA, including all projects undertaken, PPCP updates and an assessment of the effectiveness of these actions.

Work to reduce infiltration and inflow continued throughout this period. The engineering firm EVB was contracted to complete an Inflow and Infiltration analysis study, including an overview of all pumping stations and their current capacities. This will assist in identifying areas of concern and help with future work planning.

Multiple CCTV inspections were completed in various areas of suspected or known infiltration, such as the northeast section, along Garry River and the intersection of St James St and Dominion St South, to determine the levels of infiltration. Contractors were hired to reline 2 sections of 600mm sanitary collection mains along the Garry River, as well as to complete spot repairs in collection

system in various areas to prevent further inflow. These repairs were completed along Kenyon ST West as identified during the CCTV work completed in 2021.

Proposed Construction of Works Update

i. Status Update

A summary of any changes or update to the schedule for the completion of the construction and commissioning operation of major process(es) / equipment groups in the Proposed Works.

Proposed works were anticipated to be constructed and commissioned within 5 years of the issuance of the current ECA (February 2021). For any delay beyond the time frame requires an application to amend the approval at a minimum of 6 months prior to ECA expiry. To date no construction work has been tendered or started at this site.

**NORTH GLENGARRY WATER WORKS
 WASTEWATER TREATMENT WORKS PERFORMANCE RESULTS**

Municipality: *North Glengarry*

Year: *2023*

Project: *Alexandria STP*

Receiving Stream: *Delisle River*

Description: *1 Pumping Station, 1 Aerated Cell, 3 Facultative Cells*

Design Capacity: *3237 m³/day*

Continuous Discharge with Phosphorous Removal

MONTH	Flows			Biochemical O ₂ Demand			Suspended Solids			Phosphorus		
	Total Flows (m ³)	Average Daily Flow (m ³)	Maximum Daily Flow (m ³)	Average Raw CBOD ₅ (mg/L)	Average Effluent CBOD ₅ (mg/L)	Percent Removal (%)	Average Raw SS (mg/L)	Average Effluent SS (mg/L)	Percent Removal (%)	Average Raw TP (mg/L)	Average Effluent TP (mg/L)	Percent Removal (%)
Jan	174,545	5,630	18,817	84.0	3.2	96.2	130.0	4.6	96.5	1.73	0.15	91.2
Feb	121,512	4,340	8,471	42.0	3.8	91.1	20.0	6.3	68.8	0.65	0.20	68.8
Mar	172,704	5,571	9,918	125.0	3.8	97.0	128.0	7.5	94.1	2.96	0.26	91.1
Apr	262,673	8,756	15,285	116.0	4.8	95.9	220.0	12.0	94.5	2.21	0.17	92.5
May	175,841	5,672	19,897	85.0	3.0	96.5	230.0	3.6	98.4	2.50	0.10	95.8
Jun	64,535	2,151	2,728	34.0	6.5	80.9	82.0	7.0	91.5	1.48	0.10	93.1
Jul	76,195	2,458	4,815	139.0	3.0	97.8	380.0	3.5	99.1	4.66	0.11	97.6
Aug	75,598	2,439	3,451	134.0	3.0	97.8	292.0	4.2	98.6	4.31	0.06	98.6
Sep	52,024	1,734	2,277	61.0	4.0	93.4	98.0	5.0	94.9	1.66	0.05	97.3
Oct	67,387	2,174	3,578	52.0	3.0	94.2	250.0	3.8	98.5	2.88	0.10	96.4
Nov	76,542	2,551	3,475	173.0	3.8	97.8	590.0	4.0	99.3	6.70	0.16	97.7
Dec	161,293	5,203	13,039	35.0	3.8	89.3	86.0	11.0	87.2	0.60	0.20	67.1
Total	1,480,848											
Average		4,057		90.0	3.8	94	208.8	6.0	93	2.70	0.14	91
Maximum			19,897	173	6.5	98	590.0	12.0	99	6.70	0.26	99
Criteria		3,237			30			40		0.50		


**NORTH GLENGARRY WATER WORKS
WASTEWATER TREATMENT PERFORMANCE RESULTS
2023**

MONTH	Ammonia			TKN			Nitrite			Nitrate		
	Average Raw Ammonia (mg/L)	Average Effluent Ammonia (mg/L)	Percent Removal (%)	Average Raw TKN (mg/L)	Average Effluent TKN (mg/L)	Percent Removal (%)	Average Raw Nitrite (mg/L)	Average Effluent Nitrite (mg/L)	Percent Removal (%)	Average Raw Nitrate (mg/L)	Average Effluent Nitrate (mg/L)	Percent Removal (%)
Jan	n/a	5.79		10.00	7.96	20.4	n/a	0.11		n/a	0.8	
Feb	n/a	7.49		8.90	8.10	9.0	n/a	0.06		n/a	0.1	
Mar	n/a	7.49		17.50	13.08	25.3	n/a	0.05		n/a	0.1	
Apr	n/a	2.73		10.60	4.50	57.5	n/a	0.06		n/a	1.0	
May	n/a	0.17		13.80	1.14	91.7	n/a	0.05		n/a	0.4	
Jun	n/a	0.23		20.60	1.20	94.2	n/a	0.06		n/a	0.4	
Jul	n/a	0.38		24.90	1.75	93.0	n/a	0.06		n/a	0.3	
Aug	n/a	0.21		22.80	1.34	94.1	n/a	0.05		n/a	0.5	
Sep	n/a	0.07		19.40	1.03	94.7	n/a	0.08		n/a	0.1	
Oct	n/a	1.92		18.40	3.00	83.7	n/a	0.06		n/a	0.1	
Nov	n/a	4.57		29.40	6.80	76.9	n/a	0.06		n/a	0.5	
Dec	n/a	4.79		7.00	8.25	-17.9	n/a	0.05		n/a	0.9	
Total												
Average		2.99		16.94	4.85	60		0.06			0.43	
Maximum		7.49		29.4	13.08	95		0.11			1.01	
Criteria												

**NORTH GLENGARRY WATER WORKS
WASTEWATER TREATMENT PERFORMANCE RESULTS
2023**

MONTH	Hydrogen Sulphide			E. coli			pH			Temp	Cl ₂
	Average Raw H ₂ S (mg/L)	Average Effluent H ₂ S (mg/L)	Percent Removal (%)	Average Raw E.coli (cts/100ml)	Average Effluent E.coli (cts/100ml)	Percent Removal (%)	Minimum Effluent pH	Average Effluent pH	Maximum Effluent pH	Average Effluent Temp (°C)	Average Effluent Cl ₂ (mg/L)
Jan	n/a	0.01		n/a	5.83		7.00	8.07	7.31	4.18	0.00
Feb	n/a	0.00		n/a	1.90		7.05	7.89	7.46	5.10	0.00
Mar	n/a	0.00		n/a	5.61		6.95	8.67	7.59	3.75	0.00
Apr	n/a	0.00		n/a	8.85		7.68	8.32	7.94	8.88	0.00
May	n/a	0.00		n/a	1.32		7.45	8.27	7.94	14.02	0.00
Jun	n/a	0.00		n/a	1.00		7.30	8.31	7.97	20.70	0.00
Jul	n/a	0.00		n/a	1.19		7.30	8.64	7.92	23.88	0.00
Aug	n/a	0.00		n/a	1.00		7.01	8.20	7.53	20.76	0.00
Sep	n/a	0.00		n/a	1.00		7.00	7.61	7.36	20.03	0.00
Oct	n/a	0.00		n/a	1.82		7.18	7.92	7.51	12.12	0.00
Nov	n/a	0.00		n/a	1.19		7.53	7.91	7.71	5.28	0.00
Dec	n/a	0.00		n/a	1.68		7.00	8.63	7.81	6.23	0.00
Total											
Average		0.00			2.0		7.62	7.62	7.62	13.06	0.00
Maximum		0.01			8.9		8.68	8.68	8.68	26.80	0.00
Criteria					200		6.0	6.5 - 8.5	9.5		0.02

Sludge Monitoring Points Identification



Notes:



PROPERTY OWNER
North Glengarry, Twp. Of
P.O. BOX 700
ALEXANDRIA, ONTARIO
K0C 1A0

REVISIONS

NO.	DESCRIPTION	DATE	BY


Twp. Of North Glengarry
PROJECT: NORTH GLENGARRY LAGOONS SLUDGE MANAGEMENT PLAN
DATE: AUG. 14, 2008

TITLE: ALEXANDRIA LAGOONS SLUDGE SAMPLING POINTS

Consulting Engineers of Ontario

MINTOSH ENGINEERS CONSULTANTS LTD. M.P.

SCALE: 1:2500
PROJECT NO: CM-08-272
SHEET NO: 2



Notes:



PROPERTY OWNER
North Glengarry, Twp. Of
P.O. BOX 700
ALEXANDRIA, ONTARIO
K0C 1A0

REVISIONS

NO.	DESCRIPTION	DATE	BY

Twp. Of North Glengarry
PROJECT: NORTH GLENGARRY LAGOONS SLUDGE MANAGEMENT PLAN
DATE: AUG. 14, 2008

TITLE: ALEXANDRIA LAGOONS SLUDGE SAMPLING POINTS

Consulting Engineers of Ontario


MINTOSH ENGINEERS CONSULTANTS LTD. M.P.

SCALE: 1:2500
PROJECT NO: CM-08-272
SHEET NO: 3


Sludge Sampling Point Volume Index

Cell A- Sample Point Sludge Volume m ³																					Total Sludge Volume (m ³)	Warning Trigger	Sludge Volume %																															
Date	1	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16	17	18	19	20	21																																	
29-Oct-19	933	609	797	996	605	1391	<u>4436</u>	<u>3810</u>	<u>1276</u>	668	567	466	506	1018	1413	864	1008	708	878	919	<u>1899</u>																				25766		49.1											
05-Jun-20	1236	927	876	1520	1132	<u>2309</u>	<u>3013</u>	<u>3404</u>	709	972	668	466	770	837	1599	1173	1238	1049	1021	1240	1189																				27347		52.2											
28-Oct-20	670	1271	743	1127	1395	<u>1784</u>	<u>3794</u>	<u>631</u>	466	628	466	304	405	972	1487	864	634	655	902	<u>1667</u>	<u>793</u>																				21660		41.3											
11-Nov-22	787	742	1142	865	1264	<u>2047</u>	<u>3710</u>	<u>2548</u>	770	466	871	162	446	724	1190	1173	922	1520	1258	<u>1560</u>	<u>1941</u>																				26104		49.8											
13-Oct-23	933	583	1009	1520	<u>2317</u>	<u>2047</u>	<u>3850</u>	<u>2322</u>	1175	972	567	770	243	837	1562	988	1094	1389	285	<u>1560</u>	<u>1523</u>																				27544		52.5											
Cell B- Sample Point Sludge Volume m ³																					Total Sludge Volume (m ³)	Warning Trigger	Sludge Volume %																															
Date	1	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16	17	18	19	20																																		
29-Oct-19	<u>2349</u>	<u>1934</u>	<u>2334</u>	<u>2892</u>	<u>3173</u>	<u>3964</u>	<u>5042</u>	<u>3458</u>	<u>2693</u>	<u>2187</u>	<u>1377</u>	<u>1013</u>	<u>1276</u>	<u>1345</u>	<u>1152</u>	<u>1631</u>	<u>1769</u>	<u>2246</u>	<u>2173</u>	<u>3176</u>																					47184	Total Sludge Volume High	92.6											
04-Jun-20	<u>2048</u>	<u>1792</u>	<u>2109</u>	<u>2892</u>	<u>4296</u>	<u>3271</u>	<u>4244</u>	<u>2987</u>	<u>1883</u>	<u>2491</u>	<u>2045</u>	<u>1053</u>	<u>749</u>	<u>1627</u>	<u>1348</u>	<u>1007</u>	<u>1691</u>	<u>2162</u>	<u>2370</u>	<u>2220</u>																					44286	Total Sludge Volume High	86.9											
28-Oct-20	<u>1897</u>	<u>2076</u>	<u>2419</u>	<u>2274</u>	<u>3959</u>	<u>4047</u>	<u>4244</u>	<u>2717</u>	<u>2288</u>	<u>1316</u>	<u>1114</u>	<u>1175</u>	<u>810</u>	<u>1236</u>	<u>1152</u>	<u>1367</u>	<u>2549</u>	<u>2303</u>	<u>2963</u>	<u>4718</u>																					46625	Total Sludge Volume High	91.5											
04-Nov-22	<u>2349</u>	<u>512</u>	<u>928</u>	<u>2892</u>	<u>4296</u>	<u>4518</u>	<u>4563</u>	<u>1078</u>	<u>1377</u>	<u>1377</u>	<u>1175</u>	<u>1073</u>	<u>567</u>	<u>1236</u>	<u>2010</u>	<u>1727</u>	<u>1509</u>	<u>2050</u>	<u>1467</u>	<u>1789</u>																					38493	Total Sludge Volume High	75.5											
13-Oct-23	<u>2319</u>	<u>1422</u>	<u>2897</u>	<u>2892</u>	<u>4072</u>	<u>4103</u>	<u>4084</u>	<u>2313</u>	<u>2693</u>	<u>2592</u>	<u>1377</u>	<u>1762</u>	<u>1154</u>	<u>1453</u>	<u>1642</u>	<u>1247</u>	<u>1353</u>	<u>1460</u>	<u>1044</u>	<u>1419</u>																					43298	Total Sludge Volume High	85.0											
Cell C- Sample Point Sludge Volume m ³																											Total Sludge Volume (m ³)	Warning Trigger	Sludge Volume %																									
Date	1	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16	17	18	19	20	21	22	23	24	25	26	27																											
28-Oct-19	<u>3516</u>	<u>3292</u>	<u>3717</u>	<u>3542</u>	<u>4517</u>	<u>3237</u>	<u>2795</u>	<u>2086</u>	<u>1701</u>	<u>1175</u>	<u>2921</u>	<u>1469</u>	<u>770</u>	<u>668</u>	<u>871</u>	<u>1073</u>	<u>2433</u>	<u>2378</u>	<u>1175</u>	<u>1175</u>	<u>1478</u>	<u>1980</u>	<u>2531</u>	<u>1699</u>	<u>1510</u>	<u>1587</u>	<u>2414</u>																								57706	Total Sludge Volume High	87.2	
04-Jun-20	<u>3578</u>	<u>3097</u>	<u>4276</u>	<u>5424</u>	<u>4920</u>	<u>2558</u>	<u>1883</u>	<u>1235</u>	<u>1377</u>	<u>1114</u>	<u>1867</u>	<u>3910</u>	<u>1073</u>	<u>1013</u>	<u>1175</u>	<u>2592</u>	<u>2174</u>	<u>2902</u>	<u>972</u>	<u>1073</u>	<u>972</u>	<u>1767</u>	<u>2836</u>	<u>1523</u>	<u>1624</u>	<u>1751</u>	<u>2911</u>																								61595	Total Sludge Volume High	93.1	
28-Oct-20	<u>3361</u>	<u>3041</u>	<u>3046</u>	<u>3819</u>	<u>4248</u>	<u>2105</u>	<u>2187</u>	<u>1377</u>	<u>1276</u>	<u>871</u>	<u>1603</u>	<u>713</u>	<u>1377</u>	<u>466</u>	<u>830</u>	<u>1681</u>	<u>1181</u>	<u>1573</u>	<u>1215</u>	<u>972</u>	<u>871</u>	<u>702</u>	<u>1128</u>	<u>1318</u>	<u>1367</u>	<u>1176</u>	<u>1349</u>																								44854	Total Sludge Volume High	67.8	
11-Nov-22	<u>3516</u>	<u>3990</u>	<u>3940</u>	<u>4373</u>	<u>4248</u>	<u>2784</u>	<u>2086</u>	<u>1580</u>	<u>1883</u>	<u>1478</u>	<u>2262</u>	<u>1577</u>	<u>851</u>	<u>851</u>	<u>1377</u>	<u>2086</u>	<u>3142</u>	<u>2727</u>	<u>1175</u>	<u>972</u>	<u>972</u>	<u>2086</u>	<u>2073</u>	<u>1816</u>	<u>1054</u>	<u>2681</u>	<u>2024</u>																									59602	Total Sludge Volume High	90.1
13-Oct-23	<u>3516</u>	<u>3013</u>	<u>3018</u>	<u>4373</u>	<u>4785</u>	<u>2988</u>	<u>1478</u>	<u>1073</u>	<u>1276</u>	<u>1580</u>	<u>1691</u>	<u>1793</u>	<u>1154</u>	<u>851</u>	<u>1154</u>	<u>1559</u>	<u>2528</u>	<u>2517</u>	<u>1175</u>	<u>1478</u>	<u>1175</u>	<u>2512</u>	<u>2683</u>	<u>1816</u>	<u>1624</u>	<u>1833</u>	<u>3657</u>																									58300	Total Sludge Volume High	88.1
<p><u> </u> Note: if a Sample Point Volume or the Total Sludge Volume is underlined, this signifies that the volume of sludge in that section is high and action might be required to obtain a uniform distribution.</p>																																																						

Sludge Volume Profile




CELL A SLUDGE DEPTHS




- Last depth reading: October 13, 2023.
- Cell volume calculated to be 52.5%.
- Sludge volume increased 2.7% from 2022 values.
- 6 locations exceeded trigger levels:
 - 5, 6, 7, 8, 20, 21
- Highest volume note in south-west corner of cell.

CELL B SLUDGE DEPTHS



- Last depth reading: October 13, 2023.
- Cell volume calculated to be 85.0%.
- Sludge volume increased 9.5% from 2022 values.
- 12 locations exceeded trigger levels:
 - 3, 4, 5, 6, 7, 8, 9, 10, 11, 12, 14, 15
- Highest volume located in north-east corner of cell.

CELL C SLUDGE DEPTHS



- Last depth reading: October 13, 2023.
- Cell volume calculated to be 88.1%.
- Sludge volume reduced 2.0% from 2022 values.
- 20 locations exceeded trigger levels:
 - 1, 2, 3, 4, 5, 6, 7, 9, 10, 11, 12, 16, 17, 18, 20, 22, 23, 24, 26, 27
- Highest volume located in north-east corner of cell.

Annual Bypass Report Appendix C

1.0- Provide the following information for each bypass that occurred at each sewage pumping station or treatment plant bypass location for the reporting year. Start with a new line for each event.

**Facility Name: Alexandria WWTP
Report Year: 2023**


Date <i>dd-mmm-yyyy</i>	Location	Type ⁽¹⁾	Start Time	Duration	Volume	Disinfect ⁽²⁾	Reason Code ⁽³⁾	Sample Results			
				Hrs	m ³			BOD ₅ (mg/L)	SS (mg/L)	TP (mg/L)	E. Coli (mg/L)
05-Apr-2023	Bishop Pumping Station	P	17:45	53.78	2000	N	1	4.4	14.9	0.17	93000
05-Apr-2023	Alx Main Pumping Station	P	17:14	40	6023	N	1 & 3	8.1	19.9	0.29	79500
01-May-2023	Alx Main Pumping Station	P	4:35	7.91	1886	N	1	11.0	43.0	0.3	
01-May-2023	Alx Manhole 160	P	6:50	3:50	444	N	1	10.0	33.0	0.6	
05-Apr-2023	Bishop Pumping Station	P	17:45	53.78	2000	N	1	4.4	14.9	0.17	93000

Comments Area for Pumping Stations and Plant Bypasses:


Type ⁽¹⁾		Disinfect ⁽²⁾	Reason Code ⁽³⁾
P: Primary	the discharge of raw sewage subject to no treatment	Y: Yes	1: Heavy Precipitation
	excludes grit removal and/or chlorination	N: No	2: Snow Melt
S: Secondary	the discharge of sewage that has undergone solids removal at the primary clarifiers but bypassed the secondary treatment process	U: Unknown	3: Equipment Failure
			4: Equipment Maintenance
			5: Sewer Problems
			6: Power Failure
			7: Exceed Design
			8: Other

2.0- Pumping Station and Plant Bypass Monthly Summary						
Facility Name: Alexandria WWTP						
Month	Primary Bypass			Secondary Bypass		
	No. of Days (days)	Duration (hours)	Volume (m ³)	No. of Days (days)	Duration (hours)	Volume (1000m ³)
January	0			0		
February	0			0		
March	0			0		
April	2.25	93.78	8023	0		
May	0.5	14.07	2330	0		
June	0			0		
July	0			0		
August	0			0		
September	0			0		
October	0			0		
November	0			0		
December	0			0		
Total	2.75	107.9	10352.9	0	0	0
AADF: Annual Average Daily Flow			% of AADF= ((Volume of Bypass/ADDF)/365)*100			
*AADF(m ³ /d) = 4,057						
Volume of Bypass as % of AADF* Daily Flow			= 0.70%			

Alexandria Monitoring Well Location




Alexandria Monitoring Sampling Results




Total Phosphorous in the downgradient well was found to be consistent lower than the result from the upgradient well results, which indicates little to no impact from the lagoon system.

Please note the initial sample results from 2013 and the last 5 years are only displayed.




E. coli has not been detected in the downgradient well and the upgradient well since 2019, which demonstrates that the lagoons have no impact on surrounding areas.

Please note results in 2019 were < 2 cfu/100mL, (represented by a reading of 2.0).




Nitrite/Nitrate samples have been below detection in most samples results. However, results from 2023 nitrate levels were increased, but these results were still minimal. Further testing may indicate if this parameter is impacting the surrounding areas,

Please note although the 2022 levels appear to be increased levels were noted however these results were <1mg/L, so represented by 1.




No sampling was completed in 2023, but historical trending results from the downgradient well results have been marginal in nature, but all results are higher than the upgradient samples. The sampling results indicate possible influence, but impact would be minimal based on results.

It is also worth noting surrounding area is agricultural, which may also be a source of nitrogen.



As historical trending has displayed intermittent increases in both upstream and downstream samples, the TKN values from 2023 are well below the upstream samples. Overall, samples are marginal in nature.

It is also worth noting surrounding area is agricultural, which may also be a source of nitrogen.



TOC sampling results were found to be lower in the downgradient well and significantly lower than the initial sample results. The annual reading appears to fluctuate over the last few years, but have been decreasing over the last 5 years.

It should be noted that all results are based on observed testing, and not from a hydrogeological standpoint.

Township of North Glengarry

Maxville Wastewater System

2023 Annual Report

Contents

1. Performance Assessment

- i. Raw Sewage Monitoring
- ii. Pre-Discharge Monitoring
- iii. Spring Discharge Monitoring

2. Groundwater and Surface Water Monitoring

3. Operational Problem Summary

4. Maintenance Summary

5. Effluent Quality Control and Assurance

6. Flow Measurement and Equipment Calibration

7. Effluent Objectives

8. Sludge Accumulation

9. Complaints

10. By-pass, Overflow, Spill or Abnormal Discharge Event

11. Other

Authorized System Alterations

- i. Alterations Summary

Efforts to Reduce System Overflows

- i. Collection System Inspection, Repair and Remediation Summary

Appendix A: Wastewater Treatment Works Performance Report

Appendix B: Sludge Monitoring Report

Appendix C: Annual Discharge Report

Appendix D: Maxville System Magmeter Flow Comparison

1. Performance Assessment


Summary and interpretation of all monitoring data collected in accordance with condition 10 and a comparison to the effluent limits outlined in condition 7, including an overview of the success and adequacy of the works.

The Wastewater System servicing the village of Maxville, Ontario is comprised of a class 2 collection system and a class 1 treatment lagoon system. The collection system is comprised of an interconnected network of sanitary service laterals, sanitary sewage mains, sanitary manholes, sewage force mains and pumping stations used to collect and transport wastewater to the treatment lagoon system. The treatment lagoons consist of a coagulant dosing system, 2 facultative lagoon cells, and chambers for both the influent and effluent flows. The influent wastewater flows are directed into one of the two lagoon cells and are dosed year-round with coagulant to aid in reducing phosphorus levels. The influent flow are rotated between cells each year by operational staff as a part of the maintenance program. The wastewater is treated through natural biological means and only discharged annually, coinciding with the Spring Thaw and peak flows conditions of the West branch of the Scotch River, as per the Environmental Compliance Approval conditions.

The influent wastewater flows entering the lagoon system is metered by a Magmeter, located prior to the Influent Splitter Chamber, and during the 2023 calendar year, 149,550m³ of untreated raw sewage was directed into the Maxville Lagoon system for treatment. There were no additional wastewater sources discharging into the system throughout this calendar year and growth to the system is very limited, however it has been noted the total influent flows have increased slightly since 2022.

Additionally, there were no CCTV inspection programs completed observed during this year, but the engineering firm have been engaged to complete an environmental assessment on the lagoon system due to the elevated rated capacity.

Figure 1: 5yrs Lagoon Influent Flow Comparison




The system operated well throughout 2023, with the raw sewage strength remaining similar to previous years, as per Table 1. The annual discharge began within 14-days of the pre-monitoring sampling, monitoring of the discharge was completed daily by operational staff and sampling was completed on five occasions at 3 sites. The required mixing ratio was always maintained based on the flow monitoring, and pH was always within allowable limits. The final effluent sampling results were well within the limits with the exception of the last TSS sample. Although the annual average for TSS was below the provincial limit of 30mg/L, it did exceed the federal limit of 25mg/L and the provincial average waste loading limit of 4,932kgs. Please see subsections below for a full summary of results and refer to Appendix A for a full summary of all flows, raw influent and treated effluent results.

The lagoon levels in each cell are monitored to ensure the cell capacities are not exceeded and no discharge will occur outside of the allowed discharge period. A high-water level trigger has been set at 76% capacity or 74.60m, at which point the township will implement a contingency plan to prevent overflow. During the 2023

calendar year the monitoring starting just before the seasonal discharge period, daily throughout the discharge and monthly outside of the discharge period when the cells were not covered by ice. No issues or concerns were noted during this period, and the levels in both cells were found to now be equalized.

Figure 2: Annual Lagoon Levels



i. Raw Sewage Monitoring

Condition 10 (3) of the ECA requires monthly raw sewage sampling at the Main Station for CBOD₅, Total Suspended Solids (TSS) and Total Phosphorus (TP). All sampling was completed as per conditions listed above; no additional samples were taken during 2023. Although TSS and TP results are slightly increased from previous years for most parameters, the sewage strength appears to be consistent with previous finding indicating not much variation in the inflowing sewage strength. Please refer to Appendix A for a full summary of the raw quality analysis.

Table 1: Annual Average Raw Sewage Monitoring Comparison

Year	Annual Average Result		
	BOD ₅ (mg/L)	TSS (mg/L)	TP (mg/L)
2023	75.5	355.5	5.27
2022	104.6	201.4	4.22
2021	183.1	170.5	4.12
2020	83.9	127	3.92
2019	112.3	222.2	3.32

ii. Pre-Discharge Monitoring

Condition 10(3) of the ECA requires the sampling and analysis of BOD₅, TSS and TP in each lagoon cell within 14 days prior to discharge commencement, which is performed to ensure that the effluent limits of each parameter are met prior to discharge. The table below summarizes the dates samples were taken and sample results within the 14-day period. In 2023 a total of 2 sets of samples were taken prior to the commencement of the discharge, all results indicated effluent sewage did not require additional treatment prior to discharge.

Table 2: Pre-Discharge Sampling Summary

Sampling Locations	Cell A			Cell B		
Effluent Parameters (mg/L)	BOD ₅	TSS	TP	BOD ₅	TSS	TP
ECA Effluent Limit (mg/L)	30	30	1	30	30	1
27-Mar-23	5	10	0.32	4	13	0.36
28-Mar-23	4	7	0.17	3	5	0.11

iii. Spring Discharge Monitoring

The 2023 annual spring discharge was a non-stop flow over 29-day period, within a calculated 675.9hrs. The discharge was started on Monday April 10, 2023, and was shut down on Monday May 8, 2023, with a total effluent volume of 268,031m³ discharged into the West Branch of the Scotch River. Throughout the discharge, daily flow monitoring was completed to ensure the flows remained within the allowable 3:1 mixing ratio.

Table 3: Discharge Flow Summary

Date	Start Time	Total hours	River Flow	Discharge Rate	Mixing Ratio	Discharge Amount
	(from Sting Ray)	(calculated)	(m ³ /s) (calculated)	(m ³ /s) (calculated)	(3:1) (calculated)	(m ³) (from Sting Ray)
10-Apr-23	10:19		1.629	0.213	7.65 : 1	
11-Apr-23	12:34	26.25	1.296	0.205	6.32 : 1	18,860.51
12-Apr-23	9:08	20.56	1.212	0.205	5.91 : 1	14,274.72
13-Apr-23	8:10	23.03	0.895	0.195	4.59 : 1	15,764.96
14-Apr-23	10:27	26.28	0.621	0.195	3.18 : 1	17,405.51
15-Apr-23	8:05	21.63	0.430	0.141	3.05 : 1	14,594.97
16-Apr-23	11:04	26.98	0.409	0.135	3.03 : 1	14,370.35
17-Apr-23	9:02	21.96	0.237	0.075	3.16 : 1	11,367.44
18-Apr-23	8:58	23.93	0.446	0.145	3.08 : 1	6,045.36
19-Apr-23	8:41	23.71	0.166	0.055	3.02 : 1	12,193.99
20-Apr-23	9:19	24.63	0.205	0.067	3.06 : 1	5,151.80
21-Apr-23	8:11	22.86	0.199	0.065	3.06 : 1	5,484.45
22-Apr-23	9:49	25.63	0.212	0.068	3.12 : 1	5,938.29
23-Apr-23	10:23	24.56	0.213	0.068	3.13 : 1	5,789.45
24-Apr-23	12:17	25.90	0.291	0.091	3.20 : 1	6,210.74
25-Apr-23	9:44	23.45	0.382	0.125	3.06 : 1	6,679.69
26-Apr-23	11:22	25.63	0.344	0.111	3.10 : 1	11,206.60
27-Apr-23	8:46	21.40	0.287	0.095	3.02 : 1	8,171.55
28-Apr-23	8:39	23.88	0.207	0.068	3.04 : 1	7,668.18
29-Apr-23	9:32	24.88	0.244	0.076	3.21 : 1	5,805.26
30-Apr-23	10:26	24.90	0.333	0.108	3.08 : 1	6,736.92
01-May-23	8:32	22.10	4.676	0.200	23.38 : 1	8,490.54
02-May-23	8:03	23.48	2.449	0.200	12.25 : 1	16,179.53
03-May-23	8:38	24.58	1.909	0.158	12.08 : 1	16,004.14
04-May-23	8:05	23.45	1.315	0.160	8.22 : 1	13,298.55
05-May-23	8:07	24.03	0.829	0.053	15.64 : 1	8,962.25
06-May-23	9:17	25.16	0.569	0.021	27.10 : 1	2,603.58
07-May-23	11:51	26.56	0.330	0.014	23.57 : 1	1,717.93
08-May-23	12:19	24.46	0.285	0.010	29.72 : 1	1,053.25

Condition 10(2) of the ECA requires that during the discharge the lagoon effluent is to be sampled at a minimum of 4 times per cell based on the % draw down. Samples are to be collected at the start of the discharge, at 33%, at 67% and on the final day. During the 2023 discharge, samples were collected 5 times

from a single point at the discharge outfall, as the cell discharges are blended before being released. The effluent discharge was also tested for acute lethality, as per federal requirements. As per the above statement the only issue observed was an elevated TSS result on the last sample. There were no operational issues noted or observed sedimentation during the sampling. Please refer to section 7 and Appendix A for further information.

2. Groundwater and Surface Water Monitoring

Summary and Interpretation of all groundwater monitoring data.

Condition 10(3) of the current ECA addresses the requirements of the monitoring program. Sampling is to be performed annually, semi-annually or three times per year depending on the parameter, as per Table 6-Groundwater Monitoring and Table 7-Surface Water Monitoring. JP2G Consultants in association with the Greer Galloway Group was retained by the Township to complete the annual monitoring program for the Maxville lagoon system. An annual report is submitted to the Ministry of Environment and to the Township upon completion each calendar year.

As per the report, the groundwater flow direction is east-northeast, consistent with historical findings and results indicate that the lagoons are having some impacts on the groundwater in the area. However, the results were well within the compliance requirements of the MOECC B-7 guideline and no potable groundwater users are within the area immediately downgradient of the site. The surface water results indicated the lagoons do not appear to have significantly impacted the water quality in the West Branch of the Scotch River and the results observed in river were significantly outside the concentrations measured in the eastern cell of the lagoons (2022 results).

3. Operational Problems

A description of any operating problems encountered and corrected.

Collection System:

- Pump failure at Manor Station
 - multiple refurbishments on a single pump due to on-going failure issues.
 - pump was taken out of service in early 2024 and replacement pump is on-site to be installed once system upgrades are completed.
- Rail System Failure at Manor Station
 - replacement of defective equipment.
- Level float failure
 - replacement of defective equipment.

Treatment System:

- Generator
 - replace defective battery.
 - internal error code inspection and repair.
- Central equalization valve partial blockage
 - external flushing truck utilized to remove blockage from pipe.

4. Maintenance

Summary of all maintenance carried out on any major structure, equipment, apparatus, mechanism, or thing forming part of the Works.

Collection System:

- Annual generator maintenance in April and December
- Annual station wet well cleaning completed in August.
- Monthly emergency generator testing, no issues noted.

- Monthly alarm signal testing.
- Monthly pest control monitoring, no issues noted.

Treatment System:

- Annual flow meter calibration in April 2023.
- Monthly pest control monitoring at equipment building, no issues noted.
- Cleaned influent chamber in May 2023.

5. Effluent Quality Control and Assurance

Summary of any effluent quality assurance or control measures undertaken in the reporting period

All sampling was performed within provincial guidelines by licensed operators, as per internal SOP's. Sampling schedules with sign off are also used to ensure that operational staff are aware of sampling requirements and timeline as per the ECA and Federal requirements.

Effluent quality control and assurances measures were undertaken by the MOE certified laboratory, Caduceon Environmental Laboratories and AGAT Laboratories, which conducts analysis for the Township.

6. Flow Measurement and Calibration

Summary of the calibration and maintenance carried out on all effluent monitoring equipment.

Annual calibration was completed by St- Laurent Instrumentation in December 2023. Calibrations were performed on all level detection units (pumping station levels and chemical tank levels), and flow sensing devices (magmeters, miltronics, etc.).

7. Effluent Objectives

A description of efforts made, and results achieved in meeting the effluent objectives of condition 6.

Sampling was completed five times throughout the discharge period and the annual average concentrations were all below the provincial ECA effluent limits, however the annual average TSS was found to exceed the provincial objectives, the Federal Wastewater System Effluent Regulations limit, and the provincial annual average waste loading limits. The last results reported for TSS was well above the allowable concentration limits, the exceedances were reported as required. This sample was the last sample taken prior to discharge shut down, there was no notation of abnormal observances during sampling or an indication the sample had an increased suspended solid appearance. An acute lethality sample was taken at the midpoint of the discharge, and the results indicated the sample was not acutely lethal. Please refer to the tables below for the summary results. A full discharge summary can be found in Appendix C.

Table 4: Provincial and Federal Effluent Sampling Results


Effluent Parameter	CBOD ₅	TSS	TP	pH	Acute Lethality
<i>Provincial Effluent Limits (mg/L)</i>	30	30	1	6.0 - 9.5	
<i>Federal Effluent Limits (mg/L)</i>	25	25			50 %
10-Apr-2023	3	11	0.35	7.11	
18-Apr-2023	6	14	0.30	7.53	0
20-Apr-2023	28	10	0.34	8.19	
25-Apr-2023	9	16	0.30	7.75	
8-May-2023	3	84	0.54	7.75	
2023 Maxville Average Concentration	9.8	27	0.37	7.02 - 8.26	0

Table 5: Provincial Calculated Waste Loading Results

Effluent Parameter	CBOD ₅	TSS	TP	pH
Provincial Average Waste Loading Limits (kgs)	4932	4932	164	
2023 Maxville Average Waste Loading (kgs)	2626.7	7236.8	98.1	

The annual average daily flow for 2023 was calculated to be 411m³/day, and the maximum daily flow for the year was reported to be 1,990m³/day. This represents 91.2% of the total rated capacity, which is within the rated capacity of this facility. Please refer to the chart below and to Appendix A for a full summary of flows, for the Maxville Sewage Treatment Works. The flow values displayed below are based on the lagoon influent flows.

Figure 3: Monthly Average and Maximum Flow Comparison



There were no reports made in regard to floating or settleable solids within the wastewater effluent. There were also no reports made that the effluent wastewater contained oil or any other substance that created a visible film, sheen, foam or discolouration to the receiving waters.


8. Sludge Accumulation

A tabulation of the volume of sludge generated in the reporting period, an outline of anticipated volumes to be generated in the next reporting period and a summary of the locations to where the sludge was disposed.

A Sludge Management Plan was created by McIntosh Perry and put into place in 2008. As part of the monitoring methods, it is recommended that sludge level should be taken annually.

Sludge levels in Cell B were collected on October 19, 2023, but levels in Cell A were not taken due to low water levels. As per the report, no points exceeded the volume/depth elevation as per setpoints developed through the plan but the total sludge volume in Cell B exceeded the trigger warning. It was also noted that warning triggers were also exceeded at Cell B outfall and as such the sludge should be removed or dispersed as per recommendations. The Township is to determine if any action is required.

Figure 4: Lagoon Cell Sludge Levels



9. Complaints

Summary of any complaints received during the reporting period and any steps taken to address the complaints.

There were no complaints within this reporting period from the wastewater system.

10. Bypass, Overflow, Spill or Abnormal Discharge Event

A summary of all bypasses, overflow, spill, abnormal discharge events.

There were no bypasses, overflows, spills, or abnormal discharge events in 2023.

11. Other

Any other information the District Manager requires from time to time.

Authorized System Alterations

i. Alterations Summary

A summary of all alterations within the reporting period as authorized by the ECA, including all alterations that pose a significant drinking water treat.

There were no alterations or additions to the collection or treatment system during this reporting period.

Efforts to Reduce System Overflows

i. Collection System Inspection, Repair and Remediation

A summary of all work completed within the reporting period as authorized by the ECA, including all projects undertaken, PPCP updates and an assessment of the effectiveness of these actions.

This system does not have a recorded history of overflows to natural environment. The of engineering firm EVB was contracted to complete an Inflow and Infiltration analysis study, including an overview of all pumping station and their current capacities. This will assist in identifying areas of concerns and help with future work planning.

NORTH GLENGARRY WATER WORKS

WASTEWATER TREATMENT WORKS PERFORMANCE RESULTS

Municipality: North Glengarry

Year: 2023

Project: Maxville WWTP

Receiving Stream: West Branch Scotch River

Description: 1 Pumping Station, 2 Facultative Cells

Design Capacity: 450 m³/day

Seasonal Discharge with Phosphorous Removal

MONTH	Flows						Biochemical Oxygen Demand				Suspended Solids			
	Total Influent Flow (m ³)	Average Daily Influent Flow (m ³)	Maximum Daily Influent Flow (m ³)	Total Effluent Flow (m ³)	Average Daily Effluent Flow (m ³)	Maximum Daily Effluent Flow (m ³)	Average Raw BOD ₅ (mg/L)	Average Effluent CBOD ₅ (mg/L)	Percent Removal (%)	Average CBOD ₅ Waste Loading (kgs)	Average Raw TSS (mg/L)	Average Effluent TSS (mg/L)	Percent Removal (%)	Average TSS Waste Loading (kgs)
January	17,382	561	1,062				84				120			
February	14,799	529	653				77				115			
March	17,428	562	854				45				120			
April	24,888	830	1,990	208,211	9,915	18,861	51	12	77	2,394	190	13	93	2,655
May	15,863	512	1,092	59,819	8,546	16,180	24	3	88	179	310	84	73	5,025
June	8,398	280	348				156				450			
July	7,348	237	266				129				160			
August	8,410	271	328				61				700			
September	6,704	223	257				106				580			
October	6,741	217	260				73				350			
November	7,687	256	278				75				330			
December	13,902	448	646				33				600			
Total	149,550			268,030										
Average	12,462	411		134,015	9,231		76	10		2,627	335	27		7,237
Maximum	24,888		1,990	208,211		18,861	156				700			
Criteria		450						30		4932		30		4932

**NORTH GLENGARRY WATER WORKS
WASTEWATER TREATMENT WORKS PERFORMANCE RESULTS
2023**



MONTH	Phosphorus				Total Kjeldahl Nitrogen			Nitrite			Nitrate		
	Average Raw TP (mg/L)	Average Effluent TP (mg/L)	Percent Removal (%)	Average TP Loading (kgs)	Average Raw TKN (mg/L)	Average Effluent TKN (mg/L)	Percent Removal (%)	Average Raw Nitrite (mg/L)	Average Effluent Nitrite (mg/L)	Percent Removal (%)	Average Raw Nitrate (mg/L)	Average Effluent Nitrate (mg/L)	Percent Removal (%)
January	2.10												
February	2.23												
March	2.47												
April	2.11	0.32	85	67		11.70							
May	2.17	0.54	75	32		3.60							
June	7.80												
July	5.75												
August	8.90												
September	7.24												
October	7.17												
November	7.15												
December	4.98												
Total													
Average	5.01	0.37		98		7.65							
Maximum	8.90					11.70							
Criteria	9.70	0.38											

**NORTH GLENGARRY WATER WORKS
WASTEWATER TREATMENT WORKS PERFORMANCE RESULTS
2023**

MONTH	Total Dissolved Solids			O-Phosphate			Ammonia			E-Coli		
	Average Raw TDS (mg/L)	Average Effluent TDS (mg/L)	Percent Removal (%)	Average Raw O-Phosphate (mg/L)	Average Effluent O-Phosphate (mg/L)	Percent Removal (%)	Average Raw Ammonia (mg/L)	Average Effluent Ammonia (mg/L)	Percent Removal (%)	Average Raw E.Coli (mg/L)	Average Effluent E.Coli (mg/L)	Percent Removal (%)
January												
February												
March												
April								5.0			2,286.7	
May								1.3			180.0	
June												
July												
August												
September												
October												
November												
December												
Total												
Average								3.2			1,233	
Maximum								5.0			2,287	
Criteria												

2022 Annual Cell A Sludge Reports

Maxville	Cell A-Sample Point Sludge Volume (m ³)																				Total Sludge Volume (m ³)	Total Sludge Volume (%)	Warning Trigger ²	
Date	1	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16	17	18	19	20	21			
12-Nov-08	1754	271	624	458	937	791	545	715	608	608	608	608	608	1038	356	624	624	937	937	624	1446	15,717	62	Total Sludge Volume is Elevated
22-Apr-09	356	312	312	562	312	146	711	392	203	608	1215	871	810	254	284	728	312	312	937	416	1067	11,119	44	
27-Apr-10	711	416	583	520	416	271	237	0	101	263	263	304	101	415	237	271	167	416	520	416	711	7,340	29	
07-Oct-10	237	354	312	208	250	312	284	277	405	243	1337	243	142	2076	356	458	354	312	312	208	284	8,963	36	
08-Dec-11	0	0	0	0	0	312	237	277	203	142	0	0	0	0	119	146	42	312	354	1186	1114	4,442	18	
24-Oct-12	119	104	146	0	146	42	166	115	101	41	0	101	203	231	47	42	104	42	42	104	356	2,249	9	
06-Oct-14	521	395	291	271	291	395	427	438	81	446	162	344	284	438	616	437	479	458	333	500	403	8,010	32	
06-Nov-15	379	437	1478	229	541	437	498	369	324	324	527	628	628	600	379	541	749	645	1082	749	379	11,923	47	
07-Nov-16	403	125	458	333	229	562	142	369	324	446	446	446	446	507	24	562	354	458	458	250	261	7,600	30	
29-Oct-19	687	458	458	500	229	500	332	323	527	425	648	547	344	738	569	604	604	604	562	770	853	11,279	45	
28-Oct-20	450	437	437	604	541	437	616	600	911	486	182	527	324	369	24	604	541	541	333	333	877	10,174	40	
11-Nov-22	521	250	250	354	146	666	759	161	223	547	243	648	446	161	759	354	874	666	874	978	521	10,400	41	





Triggers and Suggested Actions

- Sludge depth measurements were not completed due to low water levels observed in October
- All results displayed are from 2022.

2023 Annual Cell B Sludge Reports

Maxville	Cell B-Sample Point Sludge Volume (m ³)																					Total Sludge Volume (m ³)	Total Sludge Volume (%)	Warning Trigger ²	
	Date	1	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16	17	18	19	20				21
	12-Nov-08	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	
	22-Apr-09	1422	312	354	624	624	791	1185	507	405	304	203	770	446	1268	1304	624	937	1249	687	1145	1730	16,890	67	Total Sludge Volume is Elevated
	27-Apr-10	474	312	583	479	312	167	308	346	101	0	304	0	405	185	853	479	104	312	208	208	237	6,376	25	
	07-Oct-10	356	104	250	250	104	208	284	231	304	304	203	243	243	0	119	146	458	312	354	146	356	4,972	20	
	08-Dec-11	0	0	354	312	354	312	1967	231	446	142	142	101	668	0	166	208	146	520	562	312	521	7,464	30	
	24-Oct-12	237	208	250	208	146	208	166	346	243	142	304	142	203	161	166	146	104	146	104	146	237	4,011	16	
	06-Oct-14	640	333	666	479	541	395	593	254	263	263	81	101	284	392	403	520	458	187	479	208	593	8,133	32	
	06-Nov-15	640	458	333	333	229	229	735	369	225	20	243	344	344	623	640	354	125	354	770	229	261	7,857	31	
	07-Nov-16	284	354	354	562	354	562	521	277	243	344	344	547	446	623	166	21	562	562	354	354	877	8,710	35	
	29-Oct-19	924	125	333	562	291	395	379	969	648	425	324	446	385	969	616	333	500	562	500	708	379	10,772	43	
	28-Oct-20	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	
	14-Nov-22	806	541	645	812	812	624	735	554	628	527	628	527	527	484	782	708	645	770	541	645	972	13,911	55	Total Sludge Volume is Elevated
	19-Oct-23	616	895	1166	645	645	645	616	715	324	628	628	425	527	715	735	749	957	749	645	541	853	14,420	57	Total Sludge Volume is Elevated



Triggers and Suggested Actions

- Sludge depth completed on October 19, 2023 by operational staff.
- Currently Cell A is at 57% of allowable volume, which is a 2% increase from 2022.
- No single point location exceeded sludge depth triggers, but the total cell volume and 3 locations at the outfall exceeded the warning trigger.

2023 Annual Outfall Summary

Triggers	Monitoring Point	Warning ¹ - Sludge Depth Exceeds Trigger on	Monitoring Point	Warning ¹ - Sludge Depth Exceeds Trigger on	Monitoring Point	Warning ¹ - Sludge Depth Exceeds Trigger on	Monitoring Point	at the Cell A outfall, Cell B
Cell A	13	<u>12-Nov-08</u>	14	<u>12-Nov-08</u>	15		16	<u>12-Nov-08</u>
	13	<u>22-Apr-09</u>	14		15		16	<u>22-Apr-09</u>
	13		14		15		16	
	13		14	<u>07-Oct-10</u>	15		16	
	13		14		15		16	
	13		14		15		16	
	13		14		15	<u>06-Oct-14</u>	16	
	13	<u>06-Nov-15</u>	14	<u>06-Nov-15</u>	15		16	<u>06-Nov-15</u>
	13		14		15		16	<u>07-Nov-16</u>
	13		14	<u>29-Oct-19</u>	15		16	<u>29-Oct-19</u>
	13		14		15		16	<u>28-Oct-20</u>
	13		14		15	<u>11-Nov-22</u>	16	
	13		14		15		16	
Cell B	1		2		13		14	
	1	<u>22-Apr-09</u>	2		13		14	<u>22-Apr-09</u>
	1		2		13		14	
	1		2		13		14	
	1		2		13	<u>08-Dec-11</u>	14	
	1		2		13		14	
	1	<u>06-Oct-14</u>	2		13		14	
	1	<u>06-Nov-15</u>	2		13		14	<u>06-Nov-15</u>
	1		2		13		14	<u>07-Nov-16</u>
	1	<u>29-Oct-19</u>	2		13		14	<u>29-Oct-19</u>
	1		2		13		14	
	1	<u>14-Nov-22</u>	2	<u>14-Nov-22</u>	13	<u>14-Nov-22</u>	14	
	1	<u>19-Oct-23</u>	2	<u>19-Oct-23</u>	13	<u>19-Oct-23</u>	14	<u>19-Oct-23</u>

Triggers and Suggested Actions

	Note ² : If a sample point is underlined, this signifies that the volume/depth of a sludge in that section of the cell is elevated and action might be required to obtain a uniform sludge distribution
1	Trigger depth of 0.25 m near outlet is exceeded Removal or Dispersal of sludge may be required
2	More than half the <i>Total Sludge Volume</i> (25,170 m ³) noted on the ECA is estimated in each cell Depending on location of elevated sludge depths, removal or dispersal of sludge may be required
3	The trigger sludge depths (see <i>Sample Points Area</i> sheet) is exceeded in this cell At an individual locations, the sludge depth in more than 1/3 of the working depth in the cell (1.8 m); sludge removal or dispersal may be required



***Maxville
Spring
Discharge
2023***

May 2023

**Township of North Glengarry
Water Works Department**
Prepared by Angela Cullen

Maxville Spring Discharge 2023 Annual Report

Discharge Summary

The annual spring discharge met all requirements of set out in ECA#5368-8PPQA2 under section 9 (Special Operations), as listed below.

- The discharge was targeted to start during Spring peak flows as observed in the West Branch of the Scotch River.
- The annual discharge was continuously run over 29 days from Monday April 10, 2023 until Monday May 8, 2023.
- The discharge effluent flows were maintained to ensure discharge to river mixing ratio was never less than 3.02:1.

Summaries of the annual spring discharge totals and daily flow observations can be found in the tables listed below.

Parameter	Total
Total Days Discharged	29
Total Hours Discharged	675.9
Total Amount Discharge to Creek (m ³)	268,031
Average Daily Flow to Discharge (m ³)	9,573

Date	Start Time	Total hours	River Flow	Discharge Rate	Mixing Ratio	Discharge Amount
	(from Sting Ray)	(calculated)	m ³ /s (calculated)	m ³ /s (calculated)	(3:1) (calculated)	m ³ (from Sting Ray)
10-Apr-23	10:19		1.629	0.213	7.65 : 1	
11-Apr-23	12:34	26.25	1.296	0.205	6.32 : 1	18,860.51*
12-Apr-23	9:08	20.56	1.212	0.205	5.91 : 1	14,274.72
13-Apr-23	8:10	23.03	0.895	0.195	4.59 : 1	15,764.96*
14-Apr-23	10:27	26.28	0.621	0.195	3.18 : 1	17,405.51*
15-Apr-23	8:05	21.63	0.430	0.141	3.05 : 1	14,594.97*
16-Apr-23	11:04	26.98	0.409	0.135	3.03 : 1	14,370.35
17-Apr-23	9:02	21.96	0.237	0.075	3.16 : 1	11,367.44
18-Apr-23	8:58	23.93	0.446	0.145	3.08 : 1	6,045.36**
19-Apr-23	8:41	23.71	0.166	0.055	3.02 : 1	12,193.99
20-Apr-23	9:19	24.63	0.205	0.067	3.06 : 1	5,151.80
21-Apr-23	8:11	22.86	0.199	0.065	3.06 : 1	5,484.45
22-Apr-23	9:49	25.63	0.212	0.068	3.12 : 1	5,938.29
23-Apr-23	10:23	24.56	0.213	0.068	3.13 : 1	5,789.45**
24-Apr-23	12:17	25.90	0.291	0.091	3.20 : 1	6,210.74
25-Apr-23	9:44	23.45	0.382	0.125	3.06 : 1	6,679.69
26-Apr-23	11:22	25.63	0.344	0.111	3.10 : 1	11,206.60
27-Apr-23	8:46	21.40	0.287	0.095	3.02 : 1	8,171.55
28-Apr-23	8:39	23.88	0.207	0.068	3.04 : 1	7,668.18**

Date	Start Time	Total hours	River Flow	Discharge Rate	Mixing Ratio	Discharge Amount
	(from Sting Ray)	(calculated)	m ³ /s (calculated)	m ³ /s (calculated)	(3:1) (calculated)	m ³ (from Sting Ray)
29-Apr-23	9:32	24.88	0.244	0.076	3.21 : 1	5,805.26
30-Apr-23	10:26	24.90	0.333	0.108	3.08 : 1	6,736.92
01-May-23	8:32	22.10	4.676	0.200	23.38 : 1	8,490.54
02-May-23	8:03	23.48	2.449	0.200	12.25 : 1	16,179.53*
03-May-23	8:38	24.58	1.909	0.158	12.08 : 1	16,004.14*
04-May-23	8:05	23.45	1.315	0.160	8.22 : 1	13,298.55
05-May-23	8:07	24.03	0.829	0.053	15.64 : 1	8,962.25
06-May-23	9:17	25.16	0.569	0.021	27.10 : 1	2,603.58
07-May-23	11:51	26.56	0.330	0.014	23.57 : 1	1,717.93
08-May-23	12:19	24.46	0.285	0.010	29.72 : 1	1,053.25

*Note1: on a 1-minute filter was used to calculate daily total due to flow discrepancies in data log
 **Note2: flows were adjusted due to minor battery issues.

Sampling Summary

All pre-discharge monitoring requirements were met prior to commencement, as listed in Table 4 under condition 10 (Monitoring and Recording),

- 1 set of samples were taken from each cell on March 27, 2023, and March 28, 2023.
- CBOD₅, TSS and TP results were found to be well below the effluent objectives and limits.

The discharge was started 14 days after the pre-monitoring sampling. All discharge monitoring requirements were met as listed in Table 5 under condition 10 (Monitoring and Recording).

- Sampling was completed on 5 occasions at 3 separate locations (upstream of discharge, at the discharge outfall and 500m downstream of discharge confluence area).
- All sampling results, with the exception of the TSS were well below the objectives and limits.
 - The TSS annual average result was below the ECA limit, however the annual waste loading result was found to have exceeded the ECA limit. This was caused by a single sample result, which was 2.8 times higher than the ECA limit, causing an increased annual average.
- Sampling was also completed for acute lethality to meet the requirements for the Federal Wastewater Systems Effluent Regulation. The sample result indicated 0% mortality, meaning the effluent was not acutely lethal to rainbow trout.

Parameter	# Samples Taken	ECA Parameter Limits (mg/L)	Average Reading (mg/L)	ECA Average Waste Loading Limits (Kgs)	Average Waste Loading (kgs)	Result Adverse	Mortality %
Discharge Outfall							
CBOD ₅	5	30	9.8	4932	2626.7	N	
T.S.S	5	30	27.0	4932	7236.8	Y	
T.P.	5	1	0.37	164	98.1	N	
pH	29		7.11 - 8.19*				
Acute Lethality	1						0
Upstream							
CBOD ₅	5		3.2				
T.S.S	5		10.6				
T.P.	5		0.15				
pH	5		6.95 - 8.18*				


Parameter	# Samples Taken	ECA Parameter Limits (mg/L)	Average Reading (mg/L)	ECA Average Waste Loading Limits (Kgs)	Average Waste Loading (kgs)	Result Adverse	Mortality %
Downstream							
CBOD ₅	5		3.2				
T.S.S	5		9.4				
T.P.	5		0.12				
pH	5		6.91 - 8.84*				

Date	Discharge pH	Discharge Dissolved Oxygen mg/L	Discharge Temperature °C	Discharge TSS Sample mg/L	Discharge TSS Loading kg	Discharge CBOD ₅ Sample mg/L	Discharge CBOD ₅ Loading kg	Discharge TP Sample mg/L	Discharge TP Loading kg	Discharge Acute Lethality %
	(grab sample)	(grab sample)	(grab sample)	(grab sample)	(calculated)	(grab sample)	(calculated)	(grab sample)	(calculated)	(grab sample)
10-Apr-23	7.11	3.00	5.5	11		3		0.35		
11-Apr-23	7.02	4.83	12.2		207.47		56.58		6.60	
12-Apr-23	7.23	4.17	8.2		157.02		42.82		5.00	
13-Apr-23	7.44	2.45	7.2		173.41		47.29		5.52	
14-Apr-23	7.14	2.72	11.3		191.46		52.22		6.09	
15-Apr-23	7.17	5.16	12.0		160.54		43.78		5.11	
16-Apr-23	7.14	4.47	12.4		158.07		43.11		5.03	
17-Apr-23	7.37	3.41	15.1		125.04		34.10		3.98	
18-Apr-23	7.53	4.90	8.8	14	84.64	6	36.27	0.3	1.81	0
19-Apr-23	7.43	4.67	8.9		170.72		73.16		3.66	
20-Apr-23	8.19	6.30	9.3	10	51.52	28	144.25	0.34	1.75	
21-Apr-23	7.39	4.25	9.7		54.84		153.56		1.86	
22-Apr-23	8.24	6.48	12.3		59.38		166.27		2.02	
23-Apr-23	8.06	8.14	13.3		57.89		162.10		1.97	
24-Apr-23	8.22	9.69	12.0		62.11		173.90		2.11	
25-Apr-23	7.75	11.91	11.3	16	106.88	9	60.12	0.3	2.00	
26-Apr-23	8.12	9.54	11.4		179.31		100.86		3.36	
27-Apr-23	8.26	9.83	10.4		130.74		73.54		2.45	
28-Apr-23	7.53	8.75	11.6		122.69		69.01		2.30	
29-Apr-23	8.17	8.44	14.3		92.88		52.25		1.74	
30-Apr-23	7.97	8.95	12.0		107.79		60.63		2.02	
01-May-23	7.84	8.48	10.7		135.85		76.41		2.55	
02-May-23	7.78	9.19	9.7		258.87		145.62		4.85	
03-May-23	7.94	8.29	11.3		256.07		144.04		4.80	
04-May-23	7.68	7.70	10.2		212.78		119.69		3.99	
05-May-23	7.68	7.47	11.6		143.40		80.66		2.69	
06-May-23	7.65	7.76	17.1		41.66		23.43		0.78	
07-May-23	7.93	8.87	21.7		27.49		15.46		0.52	
08-May-23	7.75	8.95	12.4	84	88.47	3	3.16	0.54	0.57	
ECA Limit	6.0-9.5			30	4932	30	4932	1	164	50
# Samples	17	17	17	6	16	6	16	6	16	1
Minimum	7.02	2.45	5.5	10	27.5	3	3.2	0.30	0.52	0
Average		6.85	11.5	27	129.3	10	80.5	0.37	3.11	0
Maximum	8.26	11.91	21.7	84	258.9	28	173.9	0.54	6.60	0

Lagoon Levels

Lagoon cell levels were measured from Cell A and Cell B in April, prior to discharge commencement and a discrepancy between the cell heights were noted, in which Cell A was 0.15m higher than Cell B. This is consistent with previous finding back to late August 2022. The cell levels were monitored daily throughout the discharge period and summarized in Table below.

Discharge Period		
Parameter	Cell A	Cell B
Discharge Start	75.18	75.03
Discharge End	73.34	73.86
Total Difference	1.84	1.17
Average Daily Discharge	-0.07	-0.07




Issues


Observed issues noted during this discharge period were minor in nature and include the following:

- Minor battery issues, causing loss of trending for short periods of time, based on flow logs periods were estimated.
- Minor issues with data collection and flow loss, 1 minute filter was applied to compensate for trending drop-out.
- As per operational staff, foam intermittently observed at discharge outfall, caused by effluent flow velocity and discharge outfall configuration. Once flows were below 100L/s foaming was no longer observed.
 - foam never noted near mixing zone.
- No noted issues in ERIS e-logs.
- 2 days after the discharge was completed, the interconnecting piping was flushed to remove any blockage and debris so cell levels can equalize, as previously observed.


System Station Flow Comparisons




Manor Station					
Month	2019	2020	2021	2022	2023
January	1,636	1,755	1,531	1,562	2,894
February	1,417	1,530	1,272	1,654	2,566
March	2,181	2,633	2,259	2,605	2,952
April	2,201	1,966	1,588	2,401	3,380
May	1,843	1,695	1,766	2,017	2,437
June	1,617	1,501	1,466	1,859	1,750
July	1,507	1,497	1,465	1,863	1,844
August	1,535	1,693	1,375	1,963	1,704
September	1,590	1,500	1,417	2,127	1,724
October	1,712	1,786	1,507	2,233	1,475
November	1,937	1,857	1,733	1,943	1,762
December	1,690	1,955	1,903	2,244	2,360
Annual	20,866	21,367	19,284	24,471	26,850



Main Station					
Month	2019	2020	2021	2022	2023
January	16,875	27,201	12,056	9,161	18,864
February	15,266	15,535	11,010	12,113	15,457
March	23,932	28,496	19,874	23,348	17,430
April	37,403	21,512	13,432	21,067	25,509
May	33,625	14,503	11,144	14,431	16,720
June	20,617	10,729	7,483	11,150	8,514
July	14,803	10,843	7,525	7,560	7,431
August	12,063	12,729	6,291	7,504	8,280
September	10,919	11,457	5,773	8,924	6,559
October	12,079	13,929	6,924	9,673	6,665
November	17,706	12,937	8,289	8,993	7,692
December	16,922	16,586	10,500	12,276	14,105
Annual	232,210	196,457	120,301	146,199	153,227




Lagoon Influent					
Month	2019	2020	2021	2022	2023
January	13,737	16,293	11,389	8,918	17,382
February	12,586	12,904	10,444	11,502	14,799
March	21,265	26,004	19,383	23,010	17,428
April	28,994	17,037	13,113	20,501	24,888
May	24,903	11,349	10,914	14,075	15,863
June	15,693	9,161	7,697	11,090	8,398
July	11,550	8,784	7,663	7,812	7,348
August	9,772	10,186	6,305	7,453	8,410
September	8,600	9,085	5,788	8,872	6,704
October	10,483	10,909	6,987	9,019	6,741
November	14,329	10,252	8,288	8,811	7,687
December	14,069	13,577	10,442	12,552	13,902
Annual	185,980	155,542	118,413	143,615	149,550



Lagoon Effluent					
Month	2019	2020	2021	2022	2023
January					
February					
March		197,008	68,556	35,885	208,211
April	237,322	28,306	109,050	145,729	59,819
May	15,872				
June					
July					
August					
September					
October					
November					
December					
Annual	253,194	225,314	177,606	181,614	268,031

ANNUAL WASTEWATER SYSTEMS REPORT TO COUNCIL

- Alexandria WWS
- Maxville WWS



ALEXANDRIA

- Wastewater Collection
- Wastewater Treatment System

ALEXANDRIA WASTEWATER SYSTEM

- Class 2 Continuous Discharge Wastewater System
- Separate Sewer System
 - No leachate was received at MPS during this period.
- ECA 181-W601 (valid until 2027)
 - Collection system only
- ECA 9873-BQ6LTR (valid until 2026)
 - Condition all works constructed within 5 years of issuance
- Under Fisheries Act Directive (2019)
 - Action to be taken to prevent recurrence of adverse conditions
- Currently undergoing Pump Needs study through EVB

System Rating





- 25kms of collection piping and force mains
- 1585 service connections
- 3 sanitary lift stations
- 1 Pumping Station (MPS)

Collection System



- Aeration followed by 3 Facultative Treatment Cells
 - run in series
- Chemical treatment for phosphorus
 - Coagulant
- Disinfection and Dichlorination Chamber
 - Sodium Hypochlorite is disinfectant
 - Sodium Bisulfate is dechlor agent

Treatment Lagoons



FLOW SUMMARY

Raw Influent Sewage

- Metered Volume: 1,480,848m³
 - Includes flows from RV Dumping Station (seasonal operation from May 15-Oct 15)
 - No leachate from Alexandria Landfill
 - Capacity Rating: 3237 m³/day
 - Currently at 125% of the rated system capacity
- | | |
|--------------------|---------------------------|
| Maximum Daily Flow | 19,897m ³ /day |
| Average Daily Flow | 4,057m ³ /day |
- Flow are slightly increased from 2022 values
 - Significant increased flows were observed in January, February, March, April and December which coincided with significant rainfall and snow melt events
 - 4 Overflow Event in collection system.
 - All events caused by significant rainfall events, and 1 event was also caused by mechanical equipment failure.
 - All events occurred at designated overflow points.

Treated Wastewater Effluent

- Metered Volume: 1,539,737m³
- No issues noted with flow during this time, no treatment bypasses or overflows from the lagoon system

SAMPLING AND ANALYSIS

	CBOD ₅ (mg/L)	Total Suspended Solids (mg/L)	Total Phosphorous (mg/L)	Total Chlorine Residual (mg/L)	pH		E. Coli (geometric mean density) (organisms/100 mL)	Acute Lethality	
					(Min)	(Max)		% mortality	
Concentration Limits	30	40	0.5 mg/L	0.2 mg/L	6.0	9.5	< 200	50 % mortality	
Concentration Objective	25	25	0.4 mg/L	non-detect	6.5	8.5	< 150	T	D
January	3.2	4.6	0.15	0.00	7.00	8.07	5.8	0	10
February	3.8	6.3	0.20	0.00	7.05	7.89	1.9		
March	3.8	7.5	0.26	0.00	6.95	8.67	5.6		
April	4.8	12.0	0.17	0.00	7.68	8.32	8.9	0	0
May	3.0	3.6	0.10	0.00	7.45	8.27	1.3		
June	6.5	7.0	0.10	0.00	7.30	8.31	1.0		
July	3.0	3.5	0.11	0.00	7.30	8.64	1.2	0	0
August	3.0	4.2	0.06	0.00	7.01	8.20	1.0		
September	4.0	5.0	0.05	0.00	7.00	7.61	1.0		
October	3.0	3.8	0.10	0.00	7.18	7.92	1.8	0	10
November	3.8	4.0	0.16	0.00	7.53	7.91	1.2		
December	3.8	11.0	0.20	0.00	7.00	8.63	1.7		
Annual Average	3.8	6.0	0.14	0.00	6.95	8.67	2.0	n/r	

- All results were within provincial and federal annual compliance limits
- All quarterly sampling was completed as required and no adverse results were observed
- Annual monitoring well sampling was completed in March 2023
 - All results are comparable to previous findings
 - Minor influence potential from total ammonia, TKN (organic nitrogen), but further investigation would be needed to confirm, if ever required.

TREATMENT CELL SLUDGE VOLUME MONITORING

Cell A




- Last depth reading: October 13, 2023.
- Cell volume calculated to be 52.5%.
- Sludge volume increased 2.7% from 2022 values.
- 6 locations exceeded trigger levels:
 - 5, 6, 7, 8, 20, 21
- Highest volume note in south-west corner of cell.

Cell B


- Last depth reading: October 13, 2023.
- Cell volume calculated to be 85.0%.
- Sludge volume increased 9.5% from 2022 values.
- 12 locations exceeded trigger levels:
 - 3, 4, 5, 6, 7, 8, 9, 10, 11, 12, 14, 15
- Highest volume located in north-east corner of cell.

Cell C


- Last depth reading: October 13, 2023.
- Cell volume calculated to be 88.1%.
- Sludge volume reduced 2.0% from 2022 values.
- 20 locations exceeded trigger levels:
 - 1, 2, 3, 4, 5, 6, 7, 9, 10, 11, 12, 16, 17, 18, 20, 22, 23, 24, 26, 27
- Highest volume located in north-east corner of cell.




CELL A SLUDGE DEPTHS



CELL B SLUDGE DEPTHS



CELL C SLUDGE DEPTHS



Operational Issues

Collection System

Well Level Monitoring Equipment	-Caused by equipment failure.	-Float system used to maintain operations. -New monitor installed
Pump Operation Issues	-Debris in impeller or grease build-up on floats preventing operation. -Loss of flow due to pump misalignment or air lock after cleaning. -Breaker Failure	-Floats and Pumps removed and cleaned -Pump backwashed and guiderails replaced. -Caused by lack of fuel, installed auxiliary fuel pump and reset breakers
Utility Failure (Hydro)	-Unplanned failure from utility source	-pumps or generators installed to maintain operations
Alarm Panel Failure	-Communication Failure	-Replaced defective boards and communicator

Treatment System

Aerator Failure	-Coupler failure during operation	-Replaced coupler and restore operations
Chemical Dosing Pump Issues	-Electrical failure due to utility power surge	-replace with spare unit
	-Dosing loss due to corrosion or leaks in pumping system	-Repair or replace fittings
	-Dosing loss due to injection line blockage	-Thaw or replace defective lines
Utility Failure (Hydro)	-Unplanned failure from utility source	-generators installed to maintain operations

SLUDGE REMOVAL PROJECT

- Bishop Water contracted through a multiple-phase contract to remove and process sludge into Geotubes for treatment and dewatering.
- Geotubes installed in 2021, after being relocated to new area on the Lagoon property after decommissioning the pre-existing tubes.
- Scheduling issues prevented on-site sludge collection work this year.
 - All water from geotubes was returned into the lagoons for treatment

Bishop Water 2022 Work Summary Report


Week	BDT	Volume Pumped	Total Polymer Usage	Average Polymer Dosage
		m ³	L	kg/BDT
Week 1	57.07	2,211.75	334.98	5.87
Week 2	31.41	1,551.94	160.80	5.12
Total	88.48	3,763.69	495.78	5.60

BDT: bone dry ton

Bishop Water 2023 Work Summary Report

Week	BDT	Volume Pumped	Total Polymer Usage	Average Polymer Dosage
		m ³	L	kg/BDT
Week 1	n/a			
Total	n/a			

BDT: bone dry ton



MAXVILLE

- Wastewater Collection
- Wastewater Treatment System

MAXVILLE WASTEWATER SYSTEM

- Class 1 Seasonal Discharge Wastewater System
- Separate Sewer System
- ECA 181-W601 (valid until 2027)
 - Collection system only
- ECA 5368-8PPQA2 (valid until amended or revoked)

System Rating



- 13kms of collection piping and force mains
- 450 service connections
- 1 sanitary lift station
- 1 Pumping Station


Collection System



- 2 Facultative Treatment Cells
 - run in parallel
- Chemical treatment for phosphorus
 - Coagulant
- Seasonal Discharge to coincide with West Branch of Scotch River Peak Flows

Treatment Lagoons





FLOW SUMMARY

Raw Influent Sewage

- Metered Volume: 149,550m³
 - Capacity Rating: 450 m³/day
 - Currently at 91.2% of the rated system capacity

Maximum Daily Flow	1,990m ³ /day
Average Daily Flow	411m ³ /day

- Flow are slightly increased from 2022 values
 - Significant increased flows were observed in January, March, May and December which coincided with significant rainfall and snow melt events.
- No bypass event noted during this reporting season

Treated Wastewater Effluent

- Metered Volume: 268,031m³
- Spring Discharge completed over 29-day period from April 10 until May 8
- No issues noted with flow during this time, no treatment bypasses or overflows from the lagoon system

SAMPLING AND ANALYSIS

Parameters	CBOD ₅ (mg/L)	Total Suspended Solids (mg/L)	Total Phosphorous (mg/L)	pH	Acute Lethality % mortality
Provincial Concentration Limits	30	30	1	6.0 - 9.5	
Federal Concentration Limits	25	25			50
10-Apr-2023	3	11	0.35	7.11	
18-Apr-2023	6	14	0.30	7.53	0
20-Apr-2023	28	10	0.34	8.19	
25-Apr-2023	9	16	0.30	7.75	
8-May-2023	3	84	0.54	7.75	
Annual Average	9.8	27	0.37	7.02 - 8.26	n/r

Effluent Parameter	CBOD ₅	TSS	TP
Provincial Average Waste Loading Limits (kgs)	4932	4932	164
2022 Maxville Average Waste Loading (kgs)	2626.7	7236.8	98.1

- Annual Spring Discharge Monitoring
 - Both cells were discharged, and water was blended before final discharge outfall
 - Samples were taken 5 times from discharge outfall to ensure we met sampling requirements in ECA
 - All results, except for TSS, were within provincial and federal annual compliance limits
 - TSS annual average exceeded federal limit
 - Report of exceedance was completed.
 - TSS waste loading exceeded provincial limit
- Groundwater Monitoring
 - Completed by JP2G Consultants in association with Greer Galloway Group
 - includes groundwater sampling: May and October
 - includes surface water sampling: May, August and October
 - Results indicate there is minor impact on groundwater, however results are well below limits and no potable wells within immediate area downstream.
 - Results also indicated there was no observed impact on surface water.





TREATMENT CELL SLUDGE VOLUME MONITORING

Cell A

- Sludge depth measurements were not completed due to low water levels observed in October
- All results displayed are from 2022.

Cell B

- Sludge depth completed on October 19, 2023, by operational staff.
- Currently Cell A is at 57% of allowable volume, which is a 2% increase from 2022.
- No single point location exceeded sludge depth triggers, but the total cell volume and 3 locations at the outfall exceeded the warning trigger



Operational Issues

Collection System

Pump Operation Issues

- multiple failures, pump sent out for repair
- new pump was purchased in 2024

Station Guide Rails

- replaced defective guardrails

Level Float Issues

- replaced defective float

Treatment System

Central Equalization Valve

- after spring discharge was completed, Hydrovac used to remove partial blockage

Generator

- Replaced defective battery
- internal code, contractor brought in to repair and inspect unit.



STAFF REPORT TO COUNCIL

Report No: PW 2024-21

May 27, 2024

From: Timothy Wright, Director of Public Works

RE: Increase to the 2024 CCTV Sewer Budget

Recommended Motion:

THAT the Council of the Township of North Glengarry receive report PW 2024-21 Increase to the 2024 CCTV Sewer Budget;

AND THAT Council increase the budget for Sewer CCTV and Flushing for 2024 to \$110,000.00.

Background / Analysis:

At the March 25, 2024, Regular Meeting of Council, Council approved the award of the 2024 Sanitary Sewer CCTV Work to HydroCam for \$54,450.00 +HST (Report No. PW 2024-12). Staff noted that additional work may be completed at the provisional price up to the budgeted amount of \$90,000.00.

The Township inspects the sanitary system over a two-year period every four years. After further review, staff are recommending that Council take advantage of the competitive pricing and extend the scope of work to accomplish the remaining half of the sanitary inspections this year. This would result in no sanitary inspections next year. HydroCam has agreed to continue the work at the same rate as what was tendered.

At the tendered price, staff anticipate the total project cost will be approximately \$110,000 for the entire sanitary system versus \$180,000.00 (\$90,000.00 through the 2024 Capital Budget and \$90,000.00 anticipated through the 2025 Capital Budget). This would result in savings of roughly \$70,000.00 over the two-year period.

Alternatives:

Tender the remaining work next year as planned.

Financial Implications:

As part of the 2024 Capital Budget, Council approved \$90,000.00. Originally, the tendered price for the section of work scheduled for 2024 was \$54,450.00. Due to the competitive pricing, staff are recommending that the budget be increased to \$110,000.00 to accommodate the remaining

sanitary inspection work. The additional \$20,000.00 will be financed through the North Glengarry Sewer Reserve.

Attachments & Relevant Legislation:

Others Consulted:

Dean McDonald, Environmental Services Manager

Zoe Bougie, Director of Finance/Treasurer

Reviewed and Approved by:
Sarah Huskinson, CAO/Clerk



MEMORANDUM

To: Township of North Glengarry Council, CAO and Clerk
From: Bryan McGillis, RRCA Board of Directors Chair
Date: May 9, 2024
Subject: RRCA Welcomes New General Manager

The Raisin Region Conservation Authority’s (RRCA) Board of Directors is pleased to announce that Alison McDonald is set to become the conservation authority’s new General Manager on June 3, 2024, following the upcoming retirement of the current RRCA General Manager, Richard Pilon. McDonald presently serves as the Managing Director of Approvals at South Nation Conservation.

Alison McDonald’s extensive experience in leading high performing teams, managing complex regulatory programs, and fostering positive stakeholder relationships makes her an excellent addition to the RRCA. Her expertise in strategic direction, operational oversight, and fiscal responsibility will ensure the RRCA continues to provide high-value natural resource management programs and services to the municipalities in its watershed jurisdiction.



Alison McDonald

The RRCA Board of Directors also express their deep gratitude to outgoing General Manager Richard Pilon for his remarkable 37-year career at local conservation authorities, including seven years of dedicated service as General Manager. His contributions in this role have been instrumental in enhancing the RRCA’s work to protect people and property from natural hazards, conserve environmentally significant land, protect municipal drinking water at the source, foster land stewardship, and provide recreation and eco-tourism opportunities.

To help provide a seamless transition, Alison McDonald and Richard Pilon will work side-by-side during the month of June. Richard retires on June 28.

Should you have any questions, please contact Bryan McGillis at bmgillis@southstormont.ca.



MEMORANDUM

To: Township of North Glengarry Council, CAO, and Clerk
From: Lisa Van De Ligt, Team Lead, Communications and Stewardship
Date: May 21, 2024
Subject: RRCA Board of Directors meeting highlights (May 16, 2024)

The Raisin Region Conservation Authority (RRCA) Board of Directors consists of eight representatives from the RRCA's five member municipalities: City of Cornwall and Townships of North Glengarry, South Glengarry, South Stormont, and North Stormont.

Following every Board meeting, councils, CAOs and clerks of the RRCA's five member municipalities are sent meeting highlights and the date of the next meeting. The RRCA Board meets monthly (except for July, August, and December, unless a special meeting is called).

May 16, 2024 RRCA Board of Directors Meeting Highlights:

- Approved minutes from the April 18, 2024 meeting can be found at <http://www.rrca.on.ca/governance>.
- Board received an update on the *Conservation Authorities Act* and associated regulatory changes. RRCA staff have been collaborating with other eastern Ontario conservation authorities to prepare an updated regulation policies manual and regulations mapping to ensure compliance with the new regulations. Meetings will be scheduled with municipalities over the next few months to discuss and review the updated policies and regulations.
- Board approved updated flood hazard mapping and regulation limit for the Eastman Drain in the Township of South Stormont and City of Cornwall.
- Board approved the submission of six funding applications to support conservation area enhancements (invasive species management and forest restoration), Drinking Water Source Protection Program outreach, and St. Lawrence River at Cornwall/Akwesasne Remedial Action Plan initiatives.

Next RRCA Board meeting date: June 20, 2024

May 10, 2024

Mayor Jamie MacDonald
Sent via email: ecdev@northglengarry.ca

Re.: National AccessAbility Week and Red Shirt DayTM 2024

I'm writing to ask if you will join me in making a pledge to commit to creating a fully accessible and inclusive society that honours and values people of all abilities during National AccessAbility Week and Red Shirt DayTM.

National AccessAbility Week is Sunday, May 26 to Saturday, June 1, 2024. This annual event allows us to come together to celebrate the valuable contributions and leadership of Canadians with disabilities.

The **Red Shirt DayTM** of Action for Accessibility and Inclusion, established by Easter Seals Canada in 2019, takes place this year on **Wednesday, May 29**. On this day, people across Canada wear red to show their support and solidarity for persons and families of those living with disabilities.

Over the past year, we have made significant progress and have had great success in raising awareness and identifying actionable steps to create more accessible and inclusive communities. Our collaborative efforts have included participation from over 20 Ontario school boards, 62 Ontario MPs and MPPs, 14 Ontario municipalities, numerous high-profile figures, and dedicated individuals. We are excited to continue this important initiative and invite you to participate by:

- **Declaring May 26 to June 1, 2024 as National AccessAbility Week** and sharing the declaration on your websites, newsletters, and social media feeds. Don't forget to tag @EasterSealsON.
- **Recognizing May 29, 2024 as the Red Shirt DayTM** of Action for Accessibility and Inclusion and encouraging all staff to wear a red shirt, making a pledge toward greater accessibility, and posting to social media. You can use hashtags #RedShirtDay and #RedForAccessAbility and tag @EasterSealsON.
- **Engaging your staff, community, and local disability and advocacy groups** to determine how you can contribute to supporting efforts to create greater accessibility and inclusion for Canadians living with disabilities.

Since 1922, Easter Seals Ontario has been a leading voice for children and youth with physical disabilities. Our enduring commitment to the well-being and empowerment of individuals with disabilities drives us to champion important initiatives like National AccessAbility Week and Red Shirt DayTM. By participating in these impactful events, you are not only acknowledging the challenges faced by Canadians with disabilities but also committing to being part of the solution.

I look forward to working together to foster a more inclusive society where every individual has the opportunity to thrive. You can learn more about Red Shirt DayTM at RedShirtDay.org and Easter Seals Ontario at EasterSeals.org.

Sincerely,



Kevin J. Collins
President & CEO
Easter Seals Ontario

THE CORPORATION OF THE TOWNSHIP OF NORTH GLENGARRY

**BY-LAW 26-2024
FOR THE YEAR 2024**

BEING A BY-LAW TO ADOPT, CONFIRM AND RATIFY MATTERS DEALT WITH BY RESOLUTION.

WHEREAS s. 5(3) of the *Municipal Act, 2001*, provides that the powers of municipal corporation are to be exercised by its Council by by-law; and

WHEREAS it is deemed expedient that the proceedings, decisions and votes of the Council of the Corporation of the Township of North Glengarry at this meeting be confirmed and adopted by by-law;

THEREFORE, the Council of the Corporation of the Township of North Glengarry enacts as follows:

1. **THAT** the action of the Council at its regular meeting of May 27th 2024, in respect to each motion passed and taken by the Council at its meetings, is hereby adopted, ratified and confirmed, as if each resolution or other action was adopted, ratified and confirmed by its separate by-law and;
2. **THAT** the Mayor and the proper officers of the Township of North Glengarry are hereby authorized and directed to do all things necessary to give effect to the said action, or to obtain approvals where required, and except where otherwise provided, The Mayor and the Clerk are hereby directed to execute all documents necessary in that behalf and to affix the corporate seal of the Township to all such documents.
3. **THAT** if due to the inclusion of a particular resolution or resolutions this By-law would be deemed invalid by a court of competent jurisdiction then Section 1 to this By-law shall be deemed to apply to all motions passed except those that would make this By-law invalid.
4. **THAT** where a “Confirming By-law” conflicts with other by-laws the other by-laws shall take precedence. Where a “Confirming By-Law” conflicts with another “Confirming By-law” the most recent by-law shall take precedence.

READ a first, second and third time, passed, signed and sealed in Open Council this 27th day of May 2024.

CAO/Clerk / Deputy Clerk

Mayor / Deputy Mayor

I, hereby certify that the forgoing is a true copy of By-Law No. 26-2024, duly adopted by the Council of the Township of North Glengarry on the 27th day of May 2024.

Date Certified

CAO/Clerk / Deputy Clerk