

# CERTIFICATE OF WATER TANKER SHUTTLE ACCREDITATION

Presented to

*North Glengarry*

Alexandria F.S. (5)

Apple Hill F.S. (5)

Maxville F.S. (5)

**Date Test Passed: September 10<sup>th</sup> 2022**

Residential and Industrial Certification (6)

Flow Achieved: 804 I.G.P.M

Liters Per Min: 3655

Two (2) Hour Test Time

Signed: Melissa Rose

Melissa Rose – Principal

This Certificate is valid for 5 years and expires September 11<sup>th</sup> 2027